

G4

Name City of Dundee
 By _____
 Address 675 Highway 99W, PO Box 201
Dundee, OR 97115

Date filed March 24, 1983
 Priority March 24 1983
 Action suspended until OK Cert

Return to applicant _____
 Date of approval NOV 22 1983

CONSTRUCTION

Date for beginning NOV 22 1984
 Date for completion OCT 1 1985

Extended to _____

Date for application of water OCT 1 1986
 Extended to _____

PROSECUTION OF WORK

Form "A" filed _____
 Form "B" filed _____
 Form "C" filed completed

FINAL PROOF

Blank mailed APR 28 1989
 Proof received _____
 Date certificate issued JUL 7 1989

Application No. G10904
 Permit No. G10148
 Certificate No. 61759

Stream Index, Page No. 2-181

FEES PAID

Date	Amount	Receipt No.
3-24-83	65.00	35678

Cert. Fee _____


FEES REFUNDED

Date	Amount	Check No.

ASSIGNMENTS

Date	To Whom	Address	Volume	Page

REMARKS



Application No. G-10904
Permit No. G10148


RECEIVED
MAY 19 1983
WATER RESOURCES DEPT.
SALEM, OREGON

DUNDEE

YAMHILL COUNTY, OREGON
Population 1,285


PREPARED BY THE
OREGON STATE HIGHWAY DIVISION
IN COOPERATION WITH
U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
36 31

August 1982



KEY TO STREET GRID

- | | | | | | |
|--|---------------------------|--|-------------|--|-----------------|
| | INTERSTATE NUMBERED ROUTE | | POST OFFICE | | PUBLIC BUILDING |
| | U.S. NUMBERED ROUTE | | SCHOOL | | COURT HOUSE |
| | STATE NUMBERED ROUTE | | CITY CENTER | | CITY HALL |
| | TERMINATION OF FA SYSTEM | | CITY LIMITS | | ARMORY |
| | DIVIDED HIGHWAY | | PUBLIC AREA | | LIBRARY |



STATE OF OREGON
COUNTY OF YAMHILL
CERTIFICATE OF WATER RIGHT

THIS CERTIFICATE ISSUED TO

CITY OF DUNDEE
675 HIGHWAY 99W
P.O. BOX 201
DUNDEE, OREGON 97115

confirms the right to use the waters of WELLS 5 AND 6 in the WILLAMETTE RIVER BASIN for the purpose of MUNICIPAL USE.

The right has been perfected under Permit G-10148. The date of priority is MARCH 24, 1983. The right is limited to not more than 0.60 CUBIC FOOT PER SECOND, BEING 0.30 CFS FROM EACH WELL, or its equivalent in case of rotation, measured at the wells.

The wells are located as follows:

NW 1/4 SE 1/4, AS PROJECTED WITHIN DLC 57, SECTION 26, T 3 S, R 3 W, W.M.; WELL 5 - 1335 FEET NORTH AND 1750 FEET WEST; WELL 6 - 1360 FEET NORTH AND 1560 FEET WEST, BOTH FROM SE CORNER SECTION 26.

The right shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the place of use under the right, and to which such right is appurtenant, is as follows:

SEE NEXT PAGE

S 1/2 SW 1/4
SECTION 30

NW 1/4 NW 1/4
SECTION 31
TOWNSHIP 3 SOUTH, RANGE 2 WEST, W.M.

W 1/2
S 1/2 SE 1/4
SECTION 25

NE 1/4
SE 1/4 NW 1/4
NE 1/4 SW 1/4
SE 1/4
SECTION 26

N 1/2 NE 1/4
SECTION 35

NE 1/4
N 1/2 NW 1/4
SE 1/4 NW 1/4
NE 1/4 SW 1/4
N 1/2 SE 1/4
SECTION 36
TOWNSHIP 3 SOUTH, RANGE 3 WEST, W.M.

The right to the use of the water for the above purpose is restricted to beneficial use on the lands or place of use described.

WITNESS the signature of the Water Resources Director, affixed this date JULY 7, 1989.

/s/ WILLIAM H. YOUNG

Water Resources Director

Recorded in State Record of Water Right Certificates numbered 61759

G-10904.BWB

STATE OF OREGON
COUNTY OF YAMHILL
PROPOSED CERTIFICATE OF WATER RIGHT

Inspector

THIS CERTIFICATE ISSUED TO

CITY OF DUNDEE
675 HIGHWAY 99W
P.O. BOX 201
DUNDEE, OREGON 97115

confirms the right to use the waters of WELLS 5 AND 6 in the WILLAMETTE RIVER BASIN for the purpose of MUNICIPAL USE.

The right has been perfected under Permit G-10148. The date of priority is MARCH 24, 1983. The right is limited to not more than 0.60 CUBIC FOOT PER SECOND, BEING 0.30 CFS FROM EACH WELL, or its equivalent in case of rotation, measured at the wells.

The wells are located as follows:

NW 1/4 SE 1/4, AS PROJECTED WITHIN DLC 57, SECTION 26,
T 3 S, R 3 W, W.M.; WELL 5 - 1335 FEET NORTH AND 1750 FEET WEST; WELL
6 - 1360 FEET NORTH AND 1560 FEET WEST, BOTH FROM SE CORNER SECTION
26.

The right shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the place of use under the right, and to which such right is appurtenant, is as follows:

S 1/2 SW 1/4
SECTION 30

NW 1/4 NW 1/4
SECTION 31
TOWNSHIP 3 SOUTH, RANGE 2 WEST, W.M.

W 1/2
S 1/2 SE 1/4
SECTION 25

NE 1/4
SE 1/4 NW 1/4
NE 1/4 SW 1/4
SE 1/4
SECTION 26

N 1/2 NE 1/4
SECTION 35

NE 1/4
N 1/2 NW 1/4
SE 1/4 NW 1/4
NE 1/4 SW 1/4
N 1/2 SE 1/4
SECTION 36
TOWNSHIP 3 SOUTH, RANGE 3 WEST, W.M.

The right to the use of the water for the above purpose is restricted to beneficial use on the lands or place of use described.

G-10904.BWB

Abstract of Permit

This is to certify that I have examined APPLICATION **G-10904** and do hereby grant the same SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

This permit is issued to **City of Dundee of 675 Highway, PO Box 201, Dundee, Oregon 97115, phone 538-3922**, for use of the waters from two wells, being 0.30 cubic foot per second of water from each well

for the PURPOSE of **municipal water supply**

that the PRIORITY OF THE RIGHT dates from **March 24, 1983**

and is limited to the amount of water which can be applied to beneficial use and shall not exceed **0.60 cfs**

measured at the point of diversion from the **wells**, or its equivalent in case of rotation with other water users.

The well is to be LOCATED: **Well 5 - 1335 feet North and 1750 feet West; Well 6 - 1360 feet North and 1560 feet West, both from the Southeast Corner of Section 26, being within the NW 1/4 SE 1/4 of Section 26, Township 3 South, Range 3 West, WM, in the County of Yamhill.**

A description of the PLACE OF USE under the permit, and to which such right is appurtenant, is as follows:

Township 3 South, Range 2 West, WM	Section 30	SE 1/4	SW 1/4
		SW 1/4	SW 1/4
	Section 31	NW 1/4	NW 1/4
Township 3 South, Range 3 West, WM	Section 25	NE 1/4	NW 1/4
		NW 1/4	NW 1/4
		SE 1/4	NW 1/4
		SW 1/4	NW 1/4
		SE 1/4	SW 1/4
		SW 1/4	SW 1/4
		NE 1/4	SW 1/4
		NW 1/4	SW 1/4
		SE 1/4	SE 1/4
		SW 1/4	SE 1/4

SEE NEXT PAGE

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times. The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

Actual construction work shall begin on or before **November 22, 1984**, and shall thereafter be prosecuted with reasonable diligence and be completed on or before **October 1, 1985**.

Complete application of the water to the proposed use shall be made on or before **October 1, 1986**.

Witness my hand this **22nd** day of **November**, 19 **83**.

WATER RESOURCES DIRECTOR

This permit is for the beneficial use of water. By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan. It is possible that the land use you propose may not be allowed if it is not in keeping with the goals and the acknowledged plan. Your city or county planning agency can advise you about the land-use plan in your area.

APPLICATION **G-10904**

PERMIT

G10148

NCR
3/22/89
KWB

INSPECTION
9/23/87
KWB

DFQ-22-241


DLC 57

SE NW
NE SW

NE 1/4

page two

Section 26	SE 1/4	SE 1/4
	SW 1/4	SE 1/4
	NE 1/4	SE 1/4
	NW 1/4	SE 1/4
	NW 1/4	NE 1/4
Section 35	NW 1/4	NE 1/4
	NE 1/4	NE 1/4
Section 36	SE 1/4	NE 1/4
	SW 1/4	NE 1/4
	NE 1/4	NE 1/4
	NW 1/4	NE 1/4
	NE 1/4	SE 1/4
	NW 1/4	SE 1/4
	NW 1/4	NW 1/4
	NE 1/4	NW 1/4
	SE 1/4	NW 1/4
	NE 1/4	SW 1/4



Application No. G-10904
Permit No. G10148

RECEIVED
MAY 19 1983
WATER RESOURCES DEPT.
SALEM, OREGON

DUNDEE


YAMHILL COUNTY, OREGON
Population 1,285

PREPARED BY THE
OREGON STATE HIGHWAY DIVISION
IN COOPERATION WITH
U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION
36 31

August 1982

LEGEND

- | | | | | | |
|--|---------------------------|--|-------------|--|-----------------|
| | INTERSTATE NUMBERED ROUTE | | POST OFFICE | | PUBLIC BUILDING |
| | U.S. NUMBERED ROUTE | | SCHOOL | | COURT HOUSE |
| | STATE NUMBERED ROUTE | | CITY CENTER | | CITY HALL |
| | TERMINATION OF FA SYSTEM | | CITY LIMITS | | ARMORY |
| | DIVIDED HIGHWAY | | PUBLIC AREA | | LIBRARY |
| | STREET OPEN FOR TRAVEL | | | | |



INFO: TODD MILLER, PUBLIC WORKS EMPLOYEE.

SOURCE: WELLS #5 & 6. BOTH WELLS HAVE 6" CASING, SANITARY SEALS & AIRLINES. WELL #5 IS 160' DEEP & WELL #6 IS 140' DEEP. SWL UNK. BOTH DRILLED IN 1977. WELLS ARE PUMPED INTO A COMMON LINE BEFORE WATER ENTERS SYSTEM. IT IS THEN BOOSTED INTO SYSTEM ~~WHERE~~ WHERE THEY FILL ONE 400,000 GALLON AND ONE 85,000 GALLON RESERVOIR. WATER IS THEN PIPED BY GRAVITY TO AREA OF USE.

PUMPS: $7\frac{1}{2}$ HP. SUBMERSIBLE W/ 4" DISCHARGE. (SAME ON EACH WELL) SET @ 115'. OUTPUT TIME @ FLOWMETER WAS $35\frac{1}{4}$ ³/MIN. PRESSURE GAUGE: 35 PSI AHEAD OF BOOSTER FROM WELLS, 165 PSI AFTER BOOSTER TO RESERVOIRS.

BOOSTER: BALDOR 20 HP. @ 1760 RPM.
PACIFIC PUMPING DDC 5" X 4"

USE: MUNICIPAL FOR CITY OF DUNDEE POP: 1410

TIE: INSPECTION

$35\frac{1}{4}$ ³/min = 0.58 CFS

9/23/87
Benjamin W. Bishop
F.I.

Application No. G-10904Permit No. Superceded
5/6/83STATE OF OREGON WATER RESOURCES DEPARTMENT **RECEIVED**Application for a Permit to Appropriate Ground Water **MAR 24 1983****WATER RESOURCES DEPT.
SALEM, OREGON**I, City of Dundee

(Name of Applicant)

of 675 Highway 99W, P. O. Box 201, Dundee, Oregon

(Mailing Address)

(City)

State of Oregon97115

(Zip Code)

Phone No. 503-538-3922

do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of Municipal Wells # 5 & 6

(Give number of wells, tile lines, infiltration galleries, etc.)

having a diameter of 6 inches and an estimated depth of 160 & 140 respectively2. The well or other source is to be located 1335 ft. N and 1750 ft. W

(N. or S.)

(E. or W.)

from the Southeast corner of Section 26

(Public Land Survey Corner)

well # 6: 1360 ft. N. and 1560 ft W.

(If there is more than one well, each must be described)

being within the NE $\frac{1}{4}$ of the SE $\frac{1}{4}$ ofSec. 26 Tp. 3 South R. 3@3w5, W. M., in the county of Yamhill

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
3 South	3 West	26	NE $\frac{1}{4}$ SW $\frac{1}{4}$	
3 South	3 West	26	SE $\frac{1}{4}$ SW $\frac{1}{4}$	
3 South	3 West	26	NW $\frac{1}{4}$ SE $\frac{1}{4}$	
3 South	3 West	26	SW $\frac{1}{4}$ SE $\frac{1}{4}$	
3 South	3 West	26	NE $\frac{1}{4}$ SE $\frac{1}{4}$	
3 South	3 West	26	SE $\frac{1}{4}$ SE $\frac{1}{4}$	
3 South	3 West	26	SE $\frac{1}{4}$ NE $\frac{1}{4}$	
3 South	3 West	35	NE $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	35	NW $\frac{1}{4}$ NE $\frac{1}{4}$	
3 South	3 West	35	NE $\frac{1}{4}$ NE $\frac{1}{4}$	
3 South	3 West	36	NW $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	36	NE $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	25	NW $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	25	SW $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	25	NE $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	25	SE $\frac{1}{4}$ NW $\frac{1}{4}$	
3 South	3 West	25	NW $\frac{1}{4}$ SW $\frac{1}{4}$	
3 South	3 West	25	SW $\frac{1}{4}$ SW $\frac{1}{4}$	
3 South	3 West	25	NE $\frac{1}{4}$ SW $\frac{1}{4}$	
3 South	3 West	25	SE $\frac{1}{4}$ SW $\frac{1}{4}$	

4. It is estimated that 75 feet of the well will require Steel casing.

(Kind)

5. Depth to water table is estimated 30 Well drilled by Bryant Well Drilling

(Feet)

6. The amount of water which the applicant intends to apply to beneficial use is³⁰..... cubic feet per second or ...135..... gallons per minute. From each well.

7. The use to which the water is to be applied isMunicipal.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

.....N/A.....

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

.....N/A.....

10. *DESCRIPTION OF WORKS*

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

.....Well #5: 7½ hp submersible pump, set at 111 feet, pumped to system through a 6 inch diameter line.

.....Well #5: 7½ hp submersible pump, set at 115 feet, pumped to system through a 6 inch diameter line.

.....began

11. Construction work ~~will begin~~ on or before.....July 1979.....

12. Construction work ~~will be~~ completed on or before.....September 1979.....

13. The water will be completely applied to the proposed use on or before.....April 1980.....


14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right.N/A.....

Application No. B-10904

Permit No.

Remarks:.....

This permit, when issued, is for the beneficial use of water. By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan. It is possible that the land use you propose may not be allowed if it is not in keeping with the goals and the acknowledged plan. Your city or county planning agency can advise you about the land-use plan in your area.



Signature of Applicant
City of Dundee, Floyd I. Aylor, Mayor

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....correction and completion.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before.....June 13,....., 19.....83.....

WITNESS my hand this13th..... day of.....April,....., 19.....83.....

.....James E. Sexson..... Water Resources Director

By 
Chris L. Hughes

RECEIVED
MAY 11 1983
WATER RESOURCES DEPT.
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the 24th day of March, 1983, at 3:15 o'clock P.M.

Application No. B-10904

Permit No.

Application No. G-10904

Permit No. Superseded
5/6/83

PC/
NCR

Permit to appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from.....

The use to which this water is to be applied is.....

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is

Actual construction work shall begin on or before and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19.....

Complete application of the water to the proposed use shall be made on or before October 1, 19.....

WITNESS my hand this day of....., 19.....

.....
Water Resources Director

November 28, 1983

City of Dundee
675 Highway
PO Box 201
Dundee, OR 97115

G-10904

G10148

378-3066

or

1-800-452-7813

(message line)

June 3, 1983

Jim Schuette
Westech Engineering, Incorporated
3421 25th Street, SE
Salem, OR 97302

Dear Mr. Schuette:

REFERENCE: File G-10904 - City of Dundee

Thank you for returning Application G-10904.

The application is now in satisfactory form and will be considered for issuance of a permit within 30 days.

Sincerely,

CHRIS L. HUGHES
Senior Water Rights Examiner

CLH:wpc

cc: City of Dundee
0056/S
6804B

Water Resources Department

MILL CREEK OFFICE PARK

555 13th STREET N.E., SALEM, OREGON 97310

PHONE

378-3066 or
1-800-452-7813
(message line)

May 24, 1983

Jim Schuette
Westech Engineering, Inc.
3421 25th St. SE
Salem, OR 97302

Dear Mr. Schuette:

REFERENCE: File G-10904- City of Dundee

Thank you for returning Application G-10904 and the maps.

Not all the corrections asked for in my last letter were made. The map show the wells to be located in the NW $\frac{1}{4}$ SE $\frac{1}{4}$ of Section 26. This does not agree with the location of the wells as listed in item 2 of the application. Please amend item 2 of the application to locate the wells in the correct $\frac{1}{4}$ $\frac{1}{4}$ Section.

In reviewing the application, another error was discovered. In item 3 of the application, Sections 30 and 31 should be located within T. 3S, R. 2W, not T. 3S, R. 3W as listed in the application. Please amend item 3 of the application to state the correct Range for Sections 30 and 31.

I am returning the application for correction. The application is endorsed and in order to retain its priority date, it must be received in this office on or before July 24, 1983.

Sincerely,

Chris L. Hughes

Chris L. Hughes
Senior Water Rights Examiner

CLH:cle

WESTECH ENGINEERING, INC.

3421 25th Street Southeast
SALEM, OREGON 97302

RECEIVED

MAY 19 1983

Phone 585-2474

WATER RESOURCES DEPT.
SALEM, OREGON

Memo
LETTER

Date 5-18-83

Subject

To Water Resources - Mill Creek Office
555 13th St. NE
Salem, Ore 97310

File 6 10904
City of Dundee

Re: your letter dated 5-16-83.

Enclosed find application & Drings
with charges as per your
request.

Jim Schutte

SIGNED

☐ Please reply

☐ No reply necessary

TECH ENGINEERING, INC.
3421 25th Street Southeast
SALEM, OREGON 97302

RECEIVED

MAY 11 1983

Memo

LETTER

Phone 585-2474

WATER RESOURCES DEPT.
SALEM, OREGON

Date 5-9-83

Subject

Water Permit
Dundee #44-WB

To Chris Hughes - water resources
mill Creek office Park
555 13th St NE
Salem, OR 97310

Enclosed find 4 copies of maps
for file # G-10904

Dundee Current Population: 1275
Projected Water Demand: .85 MGD/1990

City Recorder will be sending you
original signature sheets to you.

Jim Schuette

SIGNED

☐ Please reply

☐ No reply necessary

ST
CITY OF DUNDEE

675 HIGHWAY 99W
DUNDEE, OREGON 97115

P.O. BOX 201

PHONE: 538-3922

May 9, 1983

RECEIVED

MAY 11 1983

WATER RESOURCES DEPT.
SALEM, OREGON

Chris Hughes,
Senior Water Rights Examiner
555 13th St. N. E.
Salem, Oregon 97310

Re: G-10904

Dear Mr. Hughes:

Mr. Schuette, City Engineer, has requested the original application sent in by the City be returned to you in order that you may have the original signatures.

Thank you for your help in this matter.

Very truly yours,

Jeanne Livengood
Jeanne Livengood,
City Recorder

enc:

RISEING BOND
25% RAG CONTENT
USA

378-3066

or

1-800-452-7813
(message line)

May 16, 1983

Jim Schuette
Westech Engineering, Incorporated
3421 25th Street, SE
Salem, OR 97302

Dear Mr. Schuette:

REFERENCE: File G-10904 - City of Dundee

Thank you for returning Application G-10904 and the accompanying maps.

There are still a couple corrections to be made to the application and maps before consideration for issuance of a permit.

According to the locations of the wells from the SE Corner of Section 26 as stated in Item 2 of the application, they should both be within the NW 1/4 SE 1/4 of Section 26. However, the application lists them in the NE 1/4 SE 1/4 and the maps show them to be in the NW 1/4 SE 1/4 and SW 1/4 SE 1/4. Please amend Item 2 of the application and the maps to correctly locate the wells within the correct quarter-quarter section.

It appears from the maps that the entire NE 1/4 of Section 26 should be included as a place of use in Item 3 of the application. However, it appears that the NW 1/4 NE 1/4 was left out of the list. Please amend Item 3 of the application to include the NW 1/4 NE 1/4 of Section 26 as a place of use.

I am returning Application G-10904 and maps for correction. The application is endorsed so that in order to retain its priority date it must be received in this office on or before July 18, 1983.

Sincerely,

CHRIS L. HUGHES
Senior Water Rights Examiner

CLH:wpc
cc: City of Dundee
enclosures
6418B

378-3066

or

1-800-452-7813

(message line)

April 12, 1983

Floyd I. Aylor, Mayor
City of Dundee
PO Box 201
Dundee, OR 97115

Dear Mr. Aylor:

REFERENCE: File G-10904

Application G-10904 describing the proposed use of .60 cubic foot per second of water from two wells for municipal use; together with the maps, has been reviewed.

Since the application submitted is not our regular form, please fill out the enclosed blue form and return both of them to this office.

The maps submitted are not to a standard even Engineer's scale and are not acceptable for our purposes. Please submit a map to a standard even scale of not less than 4" = 1 mile. If the map is larger than 11" x 17", four copies are required. Please state the locations of the wells and scale of the maps on the maps.

The wells, as shown on the maps, are located in Range 3 West. Please amend Item 2 of the application to state R3W for the location of the well.

It appears from the map, when comparing the location of the place of use (I am assuming that this is within the dashed line) with Item 3 of the application that not all quarter-quarter sections are listed and some which are listed are not needed. Please amend Item 3 and/or the map to correctly locate the place of use.

Please complete Items 4 and 5 for both wells.

It appears that Well 5 is listed twice in Item 6. Please amend Item 6.

I am returning Application G-10904 for correction and completion. The application is endorsed and in order to retain its priority date, it must be received in this office on or before June 13, 1983.

Sincerely,

CHRIS L. HUGHES
Senior Water Rights Examiner

CLH:wpc
enclosure

5943B

378-3066
or
1-800-452-7813
(message line)

April 1, 1983

City of Dundee
675 Highway 99 West
PO Box 201
Dundee, OR 97115

REFERENCE: File G-10904

We have received your application for use of water for municipal purposes along with supporting data and fees. Our Receipt 35678 is enclosed. Your application has been filed and assigned number G-10904.

Applications which are received in proper form for a permit, including maps, supporting data and fees, will receive a permit shortly after the mandatory 30-day waiting period. Applications which are defective, conflict with existing rights or require additional information will be reviewed in detail and will be returned for completion or correction within 45 days.

If your application is approved, the permit authorizing the project described in the application would be subject to prior rights and require that the well be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The permit would also require that a weir, meter, or other suitable measuring device be installed, if required by the Watermaster, and a log be kept recording the amount of ground water withdrawals. If you have any questions regarding these provisions or the Well Standards, please contact this office.

Sincerely,

RALPH H. JACKSON, Supervisor
Application/Permit Section

RHJ:wpc
enclosure

0003/X
5797B

Application No. G-10904

Permit No.

STATE OF OREGON WATER RESOURCES DEPARTMENT

Application for a Permit to Appropriate Ground Water

RECEIVED

MAY 6 1983

I, City of Dundee

WATER RESOURCES DEPT.

SALEM, OREGON

of 675 Hwy 99W, PO Box 201, Dundee

(Name of Applicant)

(Mailing Address)

(City)

State of Oregon97115

(Zip Code)

Phone No. 538-3922

do hereby

make application for a permit to appropriate the following described ground waters of the State of Oregon:

1. The development will consist of Municipal Wells #5 & #6
 #5 - 6 inches (Give number of wells, tile lines, infiltration galleries, etc.)
 having a diameter of #6 - 6 inches and an estimated depth of #5 - 160 feet.
#5 - 1335 #5 - N #6 - 140 #5 - 1750 #5 - W
#6 - 1360 ft. #6 - N #6 - 1560 ft. #6 - W
 (N. or S.) (E. or W.)
2. The well or other source is to be located Southeast Section 26
 from the corner of (Public Land Survey Corner)

(If there is more than one well, each must be described)

being within the NW $\frac{1}{4}$ of the SE $\frac{1}{4}$ of
 Sec. 26 Tp. 3 South R. 3 West, W. M., in the county of Yamhill

3. Location of area to be irrigated, or place of use if use other than irrigation.

Township	Range	Section	List $\frac{1}{4}$ $\frac{1}{4}$ of Section	List use and/or number of acres to be irrigated
3 South	3 West	26	NE $\frac{1}{4}$ NE $\frac{1}{4}$	
		26	SE $\frac{1}{4}$ NE $\frac{1}{4}$	
		26	SW $\frac{1}{4}$ NE $\frac{1}{4}$	
		26	SE $\frac{1}{4}$ NW $\frac{1}{4}$	
		26	NE $\frac{1}{4}$ SW $\frac{1}{4}$	
		26	ALL SE $\frac{1}{4}$	
		35	NW $\frac{1}{4}$ NE $\frac{1}{4}$	
		35	NE $\frac{1}{4}$ NE $\frac{1}{4}$	
		25	ALL NW $\frac{1}{4}$	
		25	ALL SW $\frac{1}{4}$	
		25	SE $\frac{1}{4}$ SE $\frac{1}{4}$	
		25	SW $\frac{1}{4}$ SE $\frac{1}{4}$	
	2 West	30	SE $\frac{1}{4}$ SW $\frac{1}{4}$	
	2 West	30	SW $\frac{1}{4}$ SW $\frac{1}{4}$	
	2 West	31	NW $\frac{1}{4}$ NW $\frac{1}{4}$	
	3 West	36	ALL NE $\frac{1}{4}$	
		36	NE $\frac{1}{4}$ SE $\frac{1}{4}$	
		36	NW $\frac{1}{4}$ SE $\frac{1}{4}$	26 NW $\frac{1}{4}$ NE $\frac{1}{4}$
		36	NW $\frac{1}{4}$ NW $\frac{1}{4}$	36 SE $\frac{1}{4}$ NW $\frac{1}{4}$
		36	NE $\frac{1}{4}$ NW $\frac{1}{4}$	36 NE $\frac{1}{4}$ SW $\frac{1}{4}$

4. It is estimated that #5 - 75 feet of the well will require #6 - Steel casing.
 (Kind)

5. Depth to water table is estimated 30 Well drilled by Bryant Well Drilling
 (Feet)

9308 b

6. The amount of water which the applicant intends to apply to beneficial use is³⁰ cubic feet per second or135..... gallons per minute. from each well.

7. The use to which the water is to be applied isMunicipal Supply.....

8. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

.....N/A.....

9. If the location of the well, or other development work is less than one-fourth mile from a natural stream channel, give the distance to the channel and the difference in elevation between the stream bed and the ground surface at the source of development.

.....N/A.....

10.

DESCRIPTION OF WORKS

Include length and dimensions of supply ditch or pipeline, size and type of pump and motor, type of irrigation system to adequately describe the proposed distribution system.

Well #5: 7 1/2 hp submersible pump, electric motor

.....set at 115 feet, pumped to system thru 3 inch line.....

Well #6: 10 hp submersible pump, electric motor

.....set at 115 feet, pumped to system thru 4 inch line.....

.....began

11. Construction work ~~will begin~~ on or before.....July 1979.....

.....was

12. Construction work ~~will be~~ completed on or before.....September 1979.....

13. The water will be completely applied to the proposed use on or before.....April 1980.....

14. If the ground water supply is supplemental to an existing supply, identify the supply and existing water right. supplements other Dundee water supplies

.....water right numbers unknown.....

Application No.....G-10904.....

Permit No.....

Remarks:.....

This permit, when issued, is for the beneficial use of water. By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan. It is possible that the land use you propose may not be allowed if it is not in keeping with the goals and the acknowledged plan. Your city or county planning agency can advise you about the land-use plan in your area.

City of Dundee, Oregon

Signature of Applicant

[Signature] City Engineer

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for.....correction.....

In order to retain its priority, this application must be returned to the Water Resources Director with corrections on or before.....July 24th....., 19 83.....

WITNESS my hand this24th..... day of.....May....., 19 83.....

.....James E. Sexson..... Water Resources Director

By *Chris L. Hughes*
Chris L. Hughes

RECEIVED

MAY 19 1983

WATER RESOURCES DEPT.
SALEM, OREGON

RECEIVED

JUN 1 1983

WATER RESOURCES DEPT.
SALEM, OREGON

This instrument was first received in the office of the Water Resources Director at Salem, Oregon, on the

.....24th..... day ofMarch....., 19 83....., at ..3:15... o'clock
.....P.....M.

Application No.....G-10904.....

Permit No.....

Application No. G-10904

Permit No. 741232

PC ✓

Permit to Appropriate the Public Waters of the State of Oregon

This is to certify that I have examined the foregoing application and do hereby grant the same, **SUBJECT TO EXISTING RIGHTS INCLUDING THE EXISTING MINIMUM FLOW POLICIES ESTABLISHED BY THE WATER POLICY REVIEW BOARD** and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 0.60 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from two wells; being 0.30 cfs from each well

The use to which this water is to be applied is municipal water supply

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is Mar. 24, 1983

Actual construction work shall begin on or before and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 19.....

Complete application of the water to the proposed use shall be made on or before October 1, 19.....

WITNESS my hand this day of....., 19.....

RH Sur