

Approved: **Tony Janicek**

Digitally signed by Tony Janicek
DN: OU=Dam Safety Program, O=Oregon Water Resources
Department, CN=Tony Janicek, E=Tony.M.Janicek@water.oregon.gov
Reason: I am approving this document
Location:
Date: 2026.07.21 15:19:24-07'00'
Foxit PDF Editor Version: 12.1.9

MEMO

To: Tony Janicek, Interim Well Construction Section Manager
From: Tommy Laird, Well Construction Compliance Coordinator
Subject: Review of Water Right Application G-19488
Date: July 21, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Stacey Garrison reviewed the application. Please see Stacey's Groundwater Review.

Applicant's Well #1 (Proposed): Well #1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of proposed Well #1 may not satisfy hydraulic connection issues to surface water.