

Approved:

Tony Janicek

Digitally signed by Tony Janicek
DN: OU=Dam Safety Program, O=Oregon Water Resources
Department, CN=Tony Janicek, E=Tony.M.Janicek@water.oregon.gov
Reason: I am approving this document
Location:
Date: 2026.08.05 17:15:24-0700
Foxit PDF Editor Version: 12.1.9

MEMO

To: Tony Janicek, Interim Well Construction Manager
From: Tommy Laird, Well Construction Compliance Coordinator
Subject: Review of Water Right Application G-19493
Date: August 5, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Jen Woody reviewed the application. Please see Jen's Groundwater Review.

Applicant's Well #PROP 713 through Well #PROP 715 (Proposed): PROP 713 through PROP 715 are proposed wells, therefore they cannot be reviewed for construction. Construction of these proposed wells shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of these wells, specific attention should be paid to ensure sealing requirements are met and that the wells do not commingle aquifers.

The construction of proposed PROP 713 through PROP 715 may not satisfy hydraulic connection issues to surface water.