

Approved:

Tony Janicek

Digitally signed by Tony Janicek
DN: OU=Dam Safety Program, O=Oregon Water Resources
Department, CN=Tony Janicek, E=Tony.M.Janicek@
water.oregon.gov
Reason: I am approving this document
Location:
Date: 2026.08.10 12:23:40-07'00'
Foxit PDF Editor Version: 12.1.9

MEMO

To: Tony Janicek, Interim Well Construction Section Manager
From: Tommy Laird, Well Construction Compliance Coordinator
Subject: Review of Water Right Application G-19497
Date: August 10, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Steve Ahlquist reviewed the application. Please see Steve's Groundwater Review.

Applicant's Well #Well 1 and Well #Well 2 (Proposed): Well 1 and Well 2 are proposed wells, therefore they cannot be reviewed for construction. Construction of these proposed wells shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of these wells, specific attention should be paid to ensure sealing requirements are met and that the wells do not commingle aquifers.

The construction of proposed Well 1 and Well 2 may not satisfy hydraulic connection issues to surface water.