Approved: Tony Janicek

Digitally signed by Tony Janicek
DN: OU=Dam Safety Program, O=Oregon Water Resources Department, CN=Tony Janicek, E=Tony.M.Janicek@water.oregon.gov
Reason: I am approving this document
Location:
Date: 2026.09.02 10:47:44-07'00'
Foxit PDF Editor Version: 12.1.9

MEMO

To: Tony Janicek, Interim Well Construction Section Manager

From: Tommy Laird, Well Construction Compliance Coordinator

Subject: Review of Water Right Application G-19504

Date: September 2, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Grayson Fish reviewed the application. Please see Grayson's Groundwater Review.

Applicant's Well #WELL 3 (Proposed): WELL 3 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of proposed WELL 3 may not satisfy hydraulic connection issues to surface water.