

Approved: **Tony Janicek**

Digitally signed by Tony Janicek  
DN: cn=Tony Janicek, o=Oregon Water Resources Department, cn=Tony Janicek,  
e=Tony.M.Janicek@water.oregon.gov  
Reason: I am approving this document  
Location:  
Date: 2025.09.02 10:48:46-0700  
Foxit PDF Editor Version: 12.1.9

# MEMO

**To:** Tony Janicek, Interim Well Construction Section Manager  
**From:** Tommy Laird, Well Construction Compliance Coordinator  
**Subject:** Review of Water Right Application G-19487  
**Date:** September 2, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Travis Brown reviewed the application. Please see Travis's Groundwater Review.

Applicant's Well #Well (Proposed): Well is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of proposed Well may not satisfy hydraulic connection issues to surface water.