

Approved: **Tony Janicek**

Digitally signed by Tony Janicek  
DN: OU=Dam Safety Program, O=Oregon Water Resources Department, CN=Tony  
Janicek, E=Tony.M.Janicek@water.oregon.gov  
Reason: I am approving this document  
Location:  
Date: 2026.09.10 15:18:36-0700  
Foxit PDF Editor Version: 12.1.9

# MEMO

**To:** Tony Janicek, Interim Well Construction Section Manager  
**From:** Tommy Laird, Well Construction Compliance Coordinator  
**Subject:** Review of Water Right Application G-19505  
**Date:** September 10, 2026

The attached application was forwarded to the Well Construction Section by the Groundwater Section. Gabriela Ferreira reviewed the application. Please see Gabriela's Groundwater Review.

**Applicant's Well #1 (Proposed):** Applicant's Well #1 is a proposed well, therefore it cannot be reviewed for construction. Construction of this proposed well shall be completed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240. During construction of this well, specific attention should be paid to ensure sealing requirements are met and that the well does not commingle aquifers.

The construction of applicant's proposed Well #1 may not satisfy hydraulic connection issues to surface water.