



September 28, 2026

MARK RAMSEY
12800 SE COWBOY CT
PRINEVILLE, OR 97754

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 16596	Permit: G 16526 *	CROO0053454	CROO0053454		REJECTED	0	Unreas Burden	A WELL (L-88664)

The test was rejected for the following reason(s):

o OWRD will not grant exemptions if only minor modifications are needed such as installing an access port for water level measurement. It is recommended that the permit holder install a new cap with a measuring port or alter the existing cap to facilitate water level measurements during the pump test for well CROO 53454.

The following pump test related materials can be found on our web site at:

Pump test administrative rules: <https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186>
A booklet explaining pump tests: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test.pdf
Pump test data forms: https://www.oregon.gov/owrd/WRDFormsPDF/pump_test_coverF.pdf
Multiple well exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf>
Unreas. burden exemption request: <https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf>

Without an approved pump test, the Department may not be able to process the Claim of Beneficial Use submitted for this permit. The person or persons conducting the test need to be thoroughly familiar with all the test requirements, which are described in the Water Resources Department's administrative rules OAR 690-217.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

Byron Ebner
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File