



Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

October 02, 2026

Kinzua Hills Golf Course
PO Box 22
Fossil, OR 97830

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 16436	Permit: G 16031 *	WHEE0050342	WHEE0050342	07/22/2006	APPROVED	1	None	

The following problems were noted on at least one of the pump tests listed above:

- Water levels were not measured and reported with sufficient accuracy and precision.

Although at least one test was approved despite problems, please note that those problems may be grounds for rejecting a test submitted in the future.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

James Hootsmans

James Hootsmans
503-871-2378
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File