Oregon
Tina Kotek, Governor

Water Resources Department
725 Summer St NE, Suite A
Salem, OR 97301
(503)986-0900
Fax (503) 986-0904

November 04, 2026

REERSLEV PROPERTIES LLC
220 E 18TH AVE
JUNCTION CITY, OR 97448

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the table below:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Problems	Exemption	Well Name
G 13283	Permit: G 12568 *	LANE0006438	LANE0006438	08/06/2026	APPROVED	1		

The following problems were noted on at least one of the pump tests listed above:

- Water levels or shut in pressures were not measured during the recovery phase of the test.

Although at least one test was approved despite problems, please note that those problems may be grounds for rejecting a test submitted in the future. This pump test approval may not be used for multiple well exemptions as the test is not sufficient to approve exemptions on all the other wells on this permit. A new test should be performed on other wells prior to asking for an exemption.

Approved pump test letters will be digitally posted to the water right in WRIS; all other pump test letters will be mailed to permit holder.

Please contact me if you have any questions.

Sincerely,

James Hootsmans

James Hootsmans
503-871-2378
Groundwater Section

cc: GW Pump Test File
cc: Certificates Section/Application File