

**Oregon Water Resources Department  
Water Rights Services Division**

Water Rights Application  
Number G-17409

**Final Order**

*Appeal Rights*

This is a Final Order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.

This statement of judicial review rights does not create a right to judicial review of this order, if judicial review is otherwise precluded by law. Where no changes have been made to a Proposed Final Order on a water right application and no protests have been filed during the protest period, the Final Order is not subject to judicial review.

*Application History*

On August 9, 2010, Denis Laviolette submitted an application to the Department for a water use permit.

The Department issued a Proposed Final Order on February 22, 2011. The protest period closed April 8, 2011, and no protest was filed.

The proposed use would not impair or be detrimental to the public interest.

**Order**

Application G-17409 is therefore approved as proposed by the Proposed Final Order. **Upon payment of outstanding fees in the amount of \$325, a permit shall be issued authorizing the proposed water use.**

Failure to meet this requirement within 60 days from the date of this Final Order may result in the proposed rejection of the application.

*If you need to request additional time, your written request should be received in the Salem office of the Department within 60 days of this Final Order. The Department will evaluate the request and determine whether or not the request may be approved.*

DATED May 2 , 2011

*E. Timothy Ward*

for Phillip C. Ward, Director  
Water Resources Department

*This document was prepared by Jeana Eastman. If you have any questions about any of the statements contained in this document I am most likely the best person to answer your questions. You can reach me at 503-986-0859.*

*If you have previously filed a protest and want to know its status, please contact Patricia McCarty at 503-986-0820.*

*If you have other questions about the Department or any of its programs please contact our Customer Service Group at 503-986-0801.*

*Address all other correspondence to: Water Rights Section, Oregon Water Resources Department, 725 Summer St NE Ste A, Salem OR 97301-1266, Fax: 503-986-0901.*

DRAFT

This is not a permit.

DRAFT

STATE OF OREGON

COUNTY OF TILLAMOOK

DRAFT PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS DRAFT PERMIT IS HEREBY ISSUED TO

DENIS LAVIOLETTE  
PO BOX 432  
TILLAMOOK, OR 97141

The specific limits and conditions of the use are listed below.

APPLICATION FILE NUMBER: G-17409

SOURCE OF WATER: WELL 1, WELL 2, AND WELL 3 IN VAUGHN CREEK BASIN

PURPOSE OR USE: IRRIGATION OF 45.37 ACRES AND POND MAINTENANCE OF POND D, CONSTRUCTED UNDER PERMIT R-14906

MAXIMUM RATE: 0.22 CUBIC FOOT PER SECOND (CFS), FURTHER LIMITED TO 0.005 CFS FOR POND MAINTENANCE

PERIOD OF USE: IRRIGATION - MARCH 1 THROUGH OCTOBER 31  
POND MAINTENANCE - YEAR-ROUND

DATE OF PRIORITY: AUGUST 9, 2010

WELL LOCATIONS:

WELL 1: NE ¼ SW ¼, SECTION 1, T1S, R10W, W.M.; 1535 FEET NORTH AND 2225 FEET EAST FROM SW CORNER, SECTION 1

WELL 2: NE ¼ SW ¼, SECTION 1, T1S, R10W, W.M.; 1705 FEET NORTH AND 2250 FEET EAST FROM SW CORNER, SECTION 1

WELL 3: NE ¼ SW ¼, SECTION 1, T1S, R10W, W.M.; 1800 FEET NORTH AND 2275 FEET EAST FROM SW CORNER, SECTION 1

The amount of water used for irrigation under this right, together with the amount secured under any other right existing for the same lands, is limited to a diversion of ONE-EIGHTIETH of one cubic foot per second and 2.5 acre-feet for each acre irrigated during the irrigation season of each year.

THE PLACE OF USE IS LOCATED AS FOLLOWS:

NE ¼ SW ¼ 15.57 ACRES  
NW ¼ SW ¼ 14.03 ACRES  
SW ¼ SW ¼ 1.92 ACRES  
SE ¼ SW ¼ 8.93 ACRES AND POND MAINTENANCE  
NW ¼ SE ¼ 2.19 ACRES  
SW ¼ SE ¼ 2.73 ACRES

SECTION 1

TOWNSHIP 1 SOUTH, RANGE 10 WEST, W.M.

Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a totalizing flow meter or other suitable measuring device as approved by the Director at each point of appropriation. The permittee shall maintain the meter or measuring device in good working order.
- B. The permittee shall keep a complete record of the amount of water used each month, and shall submit a report which includes the recorded water use measurements to the Department annually or more frequently as may be required by the Director. Further, the Director may require the permittee to report general water-use information, including the place and nature of use of water under the permit.
- C. The permittee shall allow the watermaster access to the meter or measuring device; provided however, where any meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.
- D. The Director may provide an opportunity for the permittee to submit alternative measuring and reporting procedures for review and approval.

Dedicated Measuring Tube: Wells with pumps shall be equipped with an unobstructed, dedicated measuring tube pursuant to figure 200-5 in OAR 690-200.

The well(s) shall produce ground water only from the alluvial ground water reservoir.

Prior to using water from any well listed on this permit, the permittee shall ensure that the well has been assigned an OWRD Well Identification Number (Well ID tag), which shall be permanently attached to the well. The Well ID shall be used as a reference in any correspondence regarding

the well, including any reports of water use, water level, or pump test data.

#### **STANDARD CONDITIONS**

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.

If the number, location, source, or construction of any well deviates from that proposed in the permit application or required by permit conditions, this permit may be subject to cancellation, unless the Department authorizes the change in writing.

If substantial interference with a senior water right occurs due to withdrawal of water from any well listed on this permit, then use of water from the well(s) shall be discontinued or reduced and/or the schedule of withdrawal shall be regulated until or unless the Department approves or implements an alternative administrative action to mitigate the interference. The Department encourages junior and senior appropriators to jointly develop plans to mitigate interferences.

The well(s) shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times.

If the riparian area is disturbed in the process of developing a point of appropriation, the permittee shall be responsible for restoration and enhancement of such riparian area in accordance with ODFW's Fish and Wildlife Habitat Mitigation Policy OAR 635-415. For purposes of mitigation, the ODFW Fish and Wildlife Habitat Mitigation Goals and Standards, OAR 635-415, shall be followed.

The use may be restricted if the quality of downstream waters decreases to the point that those waters no longer meet existing state or federal water quality standards due to reduced flows.

Where two or more water users agree among themselves as to the manner of rotation in the use of water and such agreement is placed in writing and filed by such water users with the watermaster, and such rotation system does not infringe upon such prior rights of any water user not a party to such rotation plan, the watermaster shall distribute the water according to such agreement.

Prior to receiving a certificate of water right, the permit holder shall submit to the Water Resources Department the results of a pump test meeting the Department's standards for each point of appropriation (well), unless an exemption has been obtained in writing under OAR 690-217. The Director may require water-level or pump-test data every ten years thereafter.

This permit is for the beneficial use of water without waste. The water user is advised that new regulations may require the use of best practical technologies or conservation practices to achieve this end.

By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

Completion of construction and application of the water shall be made within five years of the date of permit issuance. If beneficial use of permitted water has not been made before this date, the permittee may submit an application for extension of time, which may be approved based upon the merit of the application.

Within one year after making beneficial use of water, the permittee shall submit a claim of beneficial use, which includes a map and report, prepared by a Certified Water Rights Examiner.

Issued

**DRAFT - THIS IS NOT A PERMIT**

---

for Phillip C. Ward, Director  
Water Resources Department