

RECEIVED

UMAT 2070

NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion. STATE ENGINEER OF OREGON SALEM, OREGON (Please type or print)

State Well No. 4N/28-11 State Permit No.

(1) OWNER: Name Leonard N. & June Crume Address 445 E. Jennie Ave. Hermiston, Oregon

(2) LOCATION OF WELL: County Driller's well number 1/4 Section 11 T. 4N R. 28 W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [X] Welded [ ] 6" Diam. from 0 ft. to 31 ft. Gage 277

(7) PERFORATIONS: Perforated? [ ] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS: Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal bentonite Depth of seal 18 ft. Was a packer used? NO Diameter of well bore to bottom of seal 9 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 5 ft. below land surface Date Jul 17, 64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Baller test 20 gal./min. with 10 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG: Diameter of well below casing 6" Depth drilled 32 ft. Depth of completed well 32 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Soil (0-5), Soil and gravel (5-12), Clay and fine gravel (12-22), Grey clay (22-28), Fine gravel and water (28-30), Sand and water (30-32)

RECEIVED

NOV 13 2006

WATER RESOURCES DEPT SALEM, OREGON

Work started July 15 1964 Completed July 17 1964 Date well drilling machine moved off of well July 17 1964

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Hershey Well Drilling (Person, firm or corporation) (Type or print) Address R.R.1, Box 552, Hermiston, Oregon

Drilling Machine Operator's License No. 143 [Signed] John Hershey (Water Well Contractor) Contractor's License No. 315 Date July 30, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)

OFFICE WELL #1



