

Groundwater Application Review Summary Form

Application # G- 18806

GW Reviewer M. Thoma Date Review Completed: 08-21-19

Summary of GW Availability and Injury Review:

Groundwater for the proposed use is either over appropriated, will not likely be available in the amounts requested without injury to prior water rights, OR will not likely be available within the capacity of the groundwater resource per Section B of the attached review form.

Summary of Potential for Substantial Interference Review:

There is the potential for substantial interference per Section C of the attached review form.

Summary of Well Construction Assessment:

The well does not appear to meet current well construction standards per Section D of the attached review form. Route through Well Construction and Compliance Section.
on 8/26/19

This is only a summary. Documentation is attached and should be read thoroughly to understand the basis for determinations and for conditions that may be necessary for a permit (if one is issued).

OK
KJ

MEMO

To: Kristopher Byrd, Well Construction and Compliance Section Manager
From: Joel Jeffery, Well Construction Program Coordinator
Subject: Review of Water Right Application G-18806
Date: August 27, 2019

The attached application was forwarded to the Well Construction and Compliance Section by Water Rights. Mike Thoma reviewed the application. Please see Mike's Groundwater Review and the Well Log.

Applicant's Well #1 (LANE 7824): Based on a review of the Well Report, Applicant's Well #1 appears to protect the groundwater resource.

The construction of Applicants Well #1 may not satisfy hydraulic connection issues.

RECEIVED

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

JUN 29 1987

PLEASE TYPE or PRINT IN INK

LANE 165/4w-8
7824

(for official use only)

(1) OWNER: WATER RESOURCES DEPT.
Name Dennis L Newman
Address 1437 Sequoia Ave
City Springfield State OR

(10) LOCATION OF WELL by legal description:
County Lane 1/4 of Section 8 of
Township 16 S Range 4 W WM.
(Township is North or South) (Range is East or West)
Tax Lot Lot Block Subdivision
MAILING ADDRESS OF WELL (or nearest address)

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 15 ft.
Static level 15 ft. below land surface. Date May 23
Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Thermal: Withdrawal ReInjection
Cable Bored Other: Piezometric Grounding Test

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 37 ft. Depth of completed well 32 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

CASING INSTALLED: Steel Plastic
Threaded Welded
6" Diam. from #1 ft. to 32 ft. Gauge .25
LINER INSTALLED: Steel Plastic
Threaded Welded
" Diam. from ft. to ft. Gauge

MATERIAL	From	To	SWL
Soil	0	14	
Sand & Gravel w/ clay	14	35	
Sand & Gravel	35	37	

(6) PERFORATIONS: Perforated? Yes No
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
gal./min. with ft. drawdown after hrs.
Air test 15 gal./min. with drill stem at 35 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Portland Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 5 sacks & pounds
How was cement grout placed? method "D"

Date work started May 23, 1987/completed May 23, 1987
Date well drilling machine moved off of well May 23 19 87

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ly D. P. Date May 23, 19 87

Was pump installed? no Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(bonded) Water Well Constructor Certification:
Bond 800682 Issued by: American (Surety Company Name)
On behalf of Pitcher Pump & Drilling (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
[Signed] Curt P. Date 5/24/87 (Water Well Constructor)

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*46868-690

PUBLIC INTEREST REVIEW FOR GROUNDWATER APPLICATIONS

TO: Water Rights Section Date 08/21/2019
 FROM: Groundwater Section M Thoma
 SUBJECT: Application G- 18806 Reviewer's Name M Thoma
 Supersedes review of _____ Date of Review(s) _____

PUBLIC INTEREST PRESUMPTION; GROUNDWATER

OAR 690-310-130 (1) *The Department shall presume that a proposed groundwater use will ensure the preservation of the public welfare, safety and health as described in ORS 537.525.* Department staff review groundwater applications under OAR 690-310-140 to determine whether the presumption is established. OAR 690-310-140 allows the proposed use be modified or conditioned to meet the presumption criteria. **This review is based upon available information and agency policies in place at the time of evaluation.**

A. GENERAL INFORMATION: Applicant's Name: Klemp County: Lane

A1. Applicant(s) seek(s) 0.6 cfs from 1 well(s) in the Willamette Basin,
Upper Willamette subbasin

A2. Proposed use Irrigation (48 ac) Seasonality: Mar. 1 – Oct. 31 (244 d)

A3. Well and aquifer data (**attach and number logs for existing wells; mark proposed wells as such under logid**):

Well	Logid	Applicant's Well #	Proposed Aquifer*	Proposed Rate(cfs)	Location (T/R-S QQ-Q)	Location, metes and bounds, e.g. 2250' N, 1200' E fr NW cor S 36
1	LANE 7824	1	Alluvium	0.6	16S/04W-8 SWSE	1150'N, 1580'W of SE cor S 8
2						

* Alluvium, CRB, Bedrock

Well	Well Elev ft msl	First Water ft bls	SWL ft bls	SWL Date	Well Depth (ft)	Seal Interval (ft)	Casing Intervals (ft)	Liner Intervals (ft)	Perforations Or Screens (ft)	Well Yield (gpm)	Draw Down (ft)	Test Type
1	335	15	15	05/23/1987	37	0-20	+1-32	-		15		A

Use data from application for proposed wells.

A4. **Comments:** _____

A5. **Provisions of the** Willamette (OAR 690-502) Basin rules relative to the development, classification and/or management of groundwater hydraulically connected to surface water **are,** or **are not,** activated by this application. (Not all basin rules contain such provisions.)
 Comments: _____

A6. **Well(s) #** _____, _____, _____, _____, _____, tap(s) an aquifer limited by an administrative restriction.
 Name of administrative area: _____
 Comments: _____

B. GROUNDWATER AVAILABILITY CONSIDERATIONS, OAR 690-310-130, 400-010, 410-0070

B1. **Based upon available data**, I have determined that groundwater* for the proposed use:

- a. is over appropriated, is not over appropriated, or **cannot be determined to be** over appropriated during any period of the proposed use. * This finding is limited to the groundwater portion of the over-appropriation determination as prescribed in OAR 690-310-130;
- b. **will not** or **will** likely be available in the amounts requested without injury to prior water rights. * This finding is limited to the groundwater portion of the injury determination as prescribed in OAR 690-310-130;
- c. **will not** or **will** likely to be available within the capacity of the groundwater resource; or
- d. **will, if properly conditioned**, avoid injury to existing groundwater rights or to the groundwater resource:
 - i. The permit should contain condition #(s) 7C (7-yr SWL); Medium Water-Use Reporting;
 - ii. The permit should be conditioned as indicated in item 2 below.
 - iii. The permit should contain special condition(s) as indicated in item 3 below;

- B2. a. **Condition** to allow groundwater production from no deeper than _____ ft. below land surface;
- b. **Condition** to allow groundwater production from no shallower than _____ ft. below land surface;
- c. **Condition** to allow groundwater production only from the _____ groundwater reservoir between approximately _____ ft. and _____ ft. below land surface;
- d. **Well reconstruction** is necessary to accomplish one or more of the above conditions. The problems that are likely to occur with this use and without reconstructing are cited below. Without reconstruction, I recommend withholding issuance of the permit until evidence of well reconstruction is filed with the Department and approved by the Groundwater Section.

Describe injury –as related to water availability– that is likely to occur without well reconstruction (interference w/ senior water rights, not within the capacity of the resource, etc): _____

B3. **Groundwater availability remarks:** Although there are water level data in the aquifer and vicinity of the applicant’s proposed POA, a thorough analysis recharge and discharge has not been performed so Over-Appropriation and Capacity of the Resource cannot be determined and so water-level reporting conditions in B1(d) are recommended. There are several permitted groundwater rights and registrations within 1 mile of the applicant’s proposed POA but it is unlikely that the applicant’s use would result in injury to these permitted water rights given the moderately high transmissivity and high storativity of the aquifer in the area and its thickness. However, standard interference conditions should be applied

C. GROUNDWATER/SURFACE WATER CONSIDERATIONS, OAR 690-09-040

C1. **690-09-040 (1):** Evaluation of aquifer confinement:

Well	Aquifer or Proposed Aquifer	Confined	Unconfined
1	Alluvium of Willamette Valley	<input type="checkbox"/>	<input checked="" type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>

Basis for aquifer confinement evaluation: Wells penetrating shallow alluvial deposits in the Willamette Valley typically encounter unconfined aquifer conditions; additionally, well logs for the area generally report similar SWL depths regardless of "First Water" depth implying a single aquifer unit

C2. **690-09-040 (2) (3):** Evaluation of distance to, and hydraulic connection with, surface water sources. All wells located a horizontal distance less than ¼ mile from a surface water source that produce water from an unconfined aquifer shall be assumed to be hydraulically connected to the surface water source. Include in this table any streams located beyond one mile that are evaluated for PSI.

Well	SW #	Surface Water Name	GW Elev ft msl	SW Elev ft msl	Distance (ft)	Hydraulically Connected?			Potential for Subst. Interfer. Assumed?	
						YES	NO	ASSUMED	YES	NO
1	1	Willamette River	320	320-330	8590	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Basis for aquifer hydraulic connection evaluation: groundwater elevations are similar to surface water elevation implying that water moves freely between surface water and groundwater

Water Availability Basin the well(s) are located within:

Willamette R > Columbia R – AB Periwinkle Cr at Gage 14174 (ID# 30200321)

C3a. **690-09-040 (4):** Evaluation of stream impacts for each well that has been determined or assumed to be **hydraulically connected and less than 1 mile** from a surface water source. Limit evaluation to instream rights and minimum stream flows that are pertinent to that surface water source, and not lower SW sources to which the stream under evaluation is tributary. Compare the requested rate against the 1% of 80% natural flow for the pertinent Water Availability Basin (WAB). If Q is not distributed by well, use full rate for each well. Any checked box indicates the well is assumed to have the potential to cause PSI.

Well	SW #	Well < ¼ mile?	Qw > 5 cfs?	Instream Water Right ID	Instream Water Right Q (cfs)	Qw > 1% ISWR?	80% Natural Flow (cfs)	Qw > 1% of 80% Natural Flow?	Interference @ 30 days (%)	Potential for Subst. Interfer. Assumed?
		<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>

C3b. **690-09-040 (4):** Evaluation of stream impacts by total appropriation for all wells determined or assumed to be **hydraulically connected and less than 1 mile** from a surface water source. **Complete only if Q is distributed among wells.** Otherwise same evaluation and limitations apply as in C3a above.

	SW #		Qw > 5 cfs?	Instream Water Right ID	Instream Water Right Q (cfs)	Qw > 1% ISWR?	80% Natural Flow (cfs)	Qw > 1% of 80% Natural Flow?	Interference @ 30 days (%)	Potential for Subst. Interfer. Assumed?
			<input type="checkbox"/>			<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>

Comments: no surface water sources were evaluated within 1 mile

C4a. **690-09-040 (5):** Estimated impacts on **hydraulically connected surface water sources greater than one mile** as a percentage of the proposed pumping rate. Limit evaluation to the effects that will occur up to one year after pumping begins. This table encompasses the considerations required by 09-040 (5)(a), (b), (c) and (d), which are not included on this form. Use additional sheets if calculated flows from more than one WAB are required.

Non-Distributed Wells													
Well	SW#	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1	1	%	%	%	%	%	%	%	%	%	%	%	%
Well Q as CFS		0	0	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0	0
Interference CFS		0	0	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06
Distributed Wells													
Well	SW#	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		%	%	%	%	%	%	%	%	%	%	%	%
Well Q as CFS													
Interference CFS													
(A) = Total Interf.		0	0	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06
(B) = 80 % Nat. Q		10100	11600	11000	9760	8430	5360	3270	2560	2540	2860	4170	8150
(C) = 1 % Nat. Q		101	116	110	97.4	84.3	53.6	32.7	25.6	25.4	28.6	41.7	81.5
(D) = (A) > (C)		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
(E) = (A / B) x 100		< 1%	< 1%	< 1%	< 1%	< 1%	< 2%	< 2%	< 3%	< 3%	< 3%	< 2%	< 1%

(A) = total interference as CFS; (B) = WAB calculated natural flow at 80% exceed. as CFS; (C) = 1% of calculated natural flow at 80% exceed. as CFS; (D) = highlight the checkmark for each month where (A) is greater than (C); (E) = total interference divided by 80% flow as percentage.

Basis for impact evaluation: results of stream-depletion modeling for the proposed use show that impacts to either surface water source will likely be less than 10% of the rate of appropriation.

C4b. **690-09-040 (5) (b)** The potential to impair or detrimentally affect the public interest is to be determined by the Water Rights Section.

C5. **If properly conditioned**, the surface water source(s) can be adequately protected from interference, and/or groundwater use under this permit can be regulated if it is found to substantially interfere with surface water:

- i. The permit should contain condition #(s) _____;
- ii. The permit should contain special condition(s) as indicated in "Remarks" below;

C6. **SW / GW Remarks and Conditions:** The applicant's proposed POAs would be producing from an aquifer that has been found to be hydraulically connected to surface water – specifically the Willamette River at a distance of over 1 mile. The proposed maximum rate of appropriation is less than 1% of the pertinent adopted perennial streamflow for each month of the WAB. Therefore, per OAR 690-009-0040(4) the POAs are assumed to **not** have the Potential for Substantial Interference

References Used:

Gannett, M. W. and R. R. Caldwell. 1998. *Geologic Framework of the Willamette Lowland Aquifer System, Oregon and Washington*. USGS Professional Paper 1424-A.

Herrera, N. B., Burns, E. R., and T. D. Conlon. 2014. *Simulation of Groundwater Flow and the Interaction of Groundwater and Surface Water in the Willamette Basin and Central Willamette Subbasin, Oregon*. USGS Scientific Investigations Report 2014-5136.

McCloughry, J. D., T. J. Wiley, M. L. Ferns, and I. P. Madin. 2010. *Digital Geologic Map of the Southern Willamette Valley, Benton, Lane, Linn, Marion, and Polk Counties, Oregon*. Oregon Dept. of Geology and Mineral Industries. Open File Report O-10-13.

O'Conner, J. E., A. Sarna-Wojcicki, K. C. Wozniak, D. J. Polette, and R. J. Fleck. *Origin, Extent, and Thickness of Quaternary Geologic Units in the Willamette Valley, Oregon*. USGS Professional Paper 1620

Oregon Department of Geology and Mineral Industries, *Geologic Map of Oregon*. <http://www.oregongeology.org/geologicmap/>

OWRD Well Log Database – Accessed 08/21/2019

Woodward, D. G., M. W. Gannett, and J. J. Vaccaro. 1998. *Hydrogeologic Framework of the Willamette Lowland Aquifer System, Oregon and Washington*. USGS Professional Paper 1424-B.

D. WELL CONSTRUCTION, OAR 690-200

D1. Well #: _____ Logid: _____

D2. **THE WELL does not appear to meet current well construction standards based upon:**

- a. review of the well log;
- b. field inspection by _____;
- c. report of CWRE _____;
- d. other: (specify) _____

D3. **THE WELL construction deficiency or other comment is described as follows:** _____

D4. **Route to the Well Construction and Compliance Section for a review of existing well construction.**

Water Availability Tables

Water Availability Analysis Detailed Reports

WILLAMETTE R > COLUMBIA R - AB PERIWINKLE CR AT GAGE 14174
WILLAMETTE BASIN

Water Availability as of 8/20/2019

Watershed ID # 30200321 (Map)
Exceedance Level 80% ▾

Date 8/20/2019
Time 3:45 PM

Water Availability Calculation
Consumptive Uses and Storages
Instream Flow Requirements
Reservations


Water Rights
Watershed Characteristics

Water Availability Calculation


Monthly Streamflow in Cubic Feet per Second
Annual Volume at 50% Exceedance in Acre-Feet

Month	Natural Stream Flow	Consumptive Uses and Storages	Expected Stream Flow	Reserved Stream Flow	Instream Flow Requirement	Net Water Available
JAN	10,100.00	1,370.00	8,730.00	0.00	1,750.00	6,980.00
FEB	11,600.00	4,290.00	7,310.00	0.00	1,750.00	5,560.00
MAR	11,000.00	4,560.00	6,440.00	0.00	1,750.00	4,690.00
APR	9,760.00	4,260.00	5,500.00	0.00	1,750.00	3,750.00
MAY	8,430.00	2,560.00	5,870.00	0.00	1,750.00	4,120.00
JUN	5,360.00	856.00	4,500.00	0.00	1,750.00	2,750.00
JUL	3,270.00	665.00	2,600.00	0.00	1,750.00	855.00
AUG	2,560.00	604.00	1,960.00	0.00	1,750.00	206.00
SEP	2,540.00	518.00	2,020.00	0.00	1,750.00	272.00
OCT	2,860.00	269.00	2,590.00	0.00	1,750.00	841.00
NOV	4,170.00	354.00	3,820.00	0.00	1,750.00	2,070.00
DEC	8,150.00	379.00	7,770.00	0.00	1,750.00	6,020.00
ANN	7,460,000.00	1,240,000.00	6,230,000.00	0.00	1,270,000.00	4,960,000.00

Water-Level Trends in Nearby Wells



Well Log Statistics for Nearby Wells



Well Location Map

