

9619
MARI...

DEC 3 1985
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 07011200
State Permit No.

(1) OWNER:

Name WALLING SAND & GRAVEL
Address P.O. Box 12009
City Salem, Oregon 97309 State

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Hand Aug Dig Shaft
Other

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Threat Withdraw Rejection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
8" Diam. from 11 ft. to 123 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills Knife
Size of perforations 3/8 in. by 2 1/2 in.
284 perforations from 100 ft. to 122 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Pumping test made? Yes No If yes, by whom
Flow: gal/min. with ft. drawdown after hrs.
Air test: 200+ gal/min. with drill stem at 123 ft. 1 hr.
Baller test: gal/min. with ft. drawdown after hrs.
Flow: g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal - Material used Portland Cement & 5% Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 13 plus Bentonite sacks
How was cement grout placed? Pumped in thru conductor pipe

Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes No Flange Size location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 2600
SW 1/4 NE 1/4 Section 6 T. 48S R. 2W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 2225 Lancaster Drive S.E.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 45 ft.
Static level 24 ft. below land surface, Date 10/27/85
Artesian pressure Int. per square inch, Date

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 126 ft. Depth of completed well 126 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Brown Clay	2	15	
Cemented Brown Sand and Gravel	15	45	
Cemented Brown Sand and Gravel			
Water Bearing	45	80	
Brown Clay	80	82	
Slightly Cemented Brown Sand and Gravel W.B.	82	100	
Brown Sand and Gravel W.B.	100	123	
Boulder or Solid Rock	123	126	

RECEIVED

MAR 15 2007

WATER RESOURCES DEPT
SALEM, OREGON

Work started 10/24/85 19 Completed 10/27/85 19
Date well drilling machine moved off of well 10/27/85 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Mark O. Bear Date 10/28/85
(Drilling Machine Operator)

Drilling Machine Operator's License No. 811
Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WELLMETER DRILLING CO.
(Person, firm or organization) (Operator/print)
Address 7365 O'Neil Rd. N.E. Salem, Oregon 97303
[Signed] Mark O. Bear
(Water Well Contractor)
Contractor's License No. 753 Date 10/28/85 19

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97309
within 30 days from the date of well completion.

SP-12852-000

RECEIVED
OVER THE COUNTER