

Groundwater Application Review Summary Form

Application # G- 19055

GW Reviewer Joe Kemper Date Review Completed: 7/14/2015

Summary of GW Availability and Injury Review:

Groundwater for the proposed use is either over appropriated, will not likely be available in the amounts requested without injury to prior water rights, OR will not likely be available within the capacity of the groundwater resource per Section B of the attached review form.

Summary of Potential for Substantial Interference Review:

There is the potential for substantial interference per Section C of the attached review form.

Summary of Well Construction Assessment:

The well does not appear to meet current well construction standards per Section D of the attached review form. Route through Well Construction and Compliance Section.

This is only a summary. Documentation is attached and should be read thoroughly to understand the basis for determinations and for conditions that may be necessary for a permit (if one is issued).

WATER RESOURCES DEPARTMENT

MEMO

July 14th, 2021

TO: **Application G- 19055**

FROM: **GW: Joe Kemper**
 (Reviewer's Name)

SUBJECT: Scenic Waterway Interference Evaluation

YES The source of appropriation is hydraulically connected to a State Scenic
 NO Waterway or its tributaries

YES
 NO Use the Scenic Waterway Condition (Condition 7J)

Per ORS 390.835, the Groundwater Section is **able** to calculate ground water interference with surface water that contributes to a Scenic Waterway. The calculated interference is distributed below

Per ORS 390.835, the Groundwater Section is **unable** to calculate ground water interference with surface water that contributes to a scenic waterway; **therefore, the Department is unable to find that there is a preponderance of evidence that the proposed use will measurably reduce the surface water flows necessary to maintain the free-flowing character of a scenic waterway**

DISTRIBUTION OF INTERFERENCE

Calculate the percentage of consumptive use by month and fill in the table below. If interference cannot be calculated, per criteria in 390.835, do not fill in the table but check the "unable" option above, thus informing Water Rights that the Department is unable to make a Preponderance of Evidence finding.

Exercise of this permit is calculated to reduce monthly flows in Rogue Scenic Waterway by the following amounts expressed as a proportion of the consumptive use by which surface water flow is reduced.

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
0.083	0.083	0.083	0.083	0.083	0.083	0.083	0.083	0.083	0.083	0.083	0.083

PUBLIC INTEREST REVIEW FOR GROUNDWATER APPLICATIONS

TO: Water Rights Section Date 7/14/2021
 FROM: Groundwater Section Joe Kemper
Reviewer's Name
 SUBJECT: Application G- 19055 Supersedes review of NA
Date of Review(s)

PUBLIC INTEREST PRESUMPTION; GROUNDWATER

OAR 690-310-130 (1) *The Department shall presume that a proposed groundwater use will ensure the preservation of the public welfare, safety and health as described in ORS 537.525. Department staff review groundwater applications under OAR 690-310-140 to determine whether the presumption is established. OAR 690-310-140 allows the proposed use be modified or conditioned to meet the presumption criteria. This review is based upon available information and agency policies in place at the time of evaluation.*

A. GENERAL INFORMATION: Applicant's Name: Jennifer Driver County: Jackson

A1. Applicant(s) seek(s) 0.056 cfs from 1 well(s) in the Rogue Basin,
Middle Rogue subbasin

A2. Proposed use Nursery (4 acres), Storage (7 AF) Seasonality: 1/1 to 12/31

A3. Well and aquifer data (attach and number logs for existing wells; mark proposed wells as such under logid):

Well	Logid	Applicant's Well #	Proposed Aquifer*	Proposed Rate(cfs)	Location (T/R-S QQ-Q)	Location, metes and bounds, e.g. 2250' N, 1200' E fr NW cor S 36
1	Proposed	1	Bedrock	0.056	34S/4W-15 NE-SW	782.7'S, 1886.5'E fr W ¼ cor S 15
2						

* Alluvium, CRB, Bedrock

Well	Well Elev ft msl	First Water ft bls	SWL ft bls	SWL Date	Well Depth (ft)	Seal Interval (ft)	Casing Intervals (ft)	Liner Intervals (ft)	Perforations Or Screens (ft)	Well Yield (gpm)	Draw Down (ft)	Test Type
1	1540	NA	10-20	NA	350	0-100	+1-100	NA	NA	25	NA	NA

Use data from application for proposed wells.

A4. **Comments:** The well is not drilled yet, and the above details are proposed in the application. SWL in the proposed well is assumed to be 10-20 feet based on well reports for wells in the immediate vicinity.

A5. **Provisions of the** Rogue (OAR 690-515) Basin rules relative to the development, classification and/or management of groundwater hydraulically connected to surface water **are, or** **are not,** activated by this application. (Not all basin rules contain such provisions.)
 Comments: The Rogue basin rules contain no such provisions.

A6. **Well(s) #** _____, _____, _____, _____, _____, tap(s) an aquifer limited by an administrative restriction.
 Name of administrative area: _____
 Comments: _____

B. GROUNDWATER AVAILABILITY CONSIDERATIONS, OAR 690-310-130, 400-010, 410-0070

B1. **Based upon available data**, I have determined that groundwater* for the proposed use:

- a. is over appropriated, is not over appropriated, or **cannot be determined to be** over appropriated during any period of the proposed use. * This finding is limited to the groundwater portion of the over-appropriation determination as prescribed in OAR 690-310-130;
- b. **will not** or **will** likely be available in the amounts requested without injury to prior water rights. * This finding is limited to the groundwater portion of the injury determination as prescribed in OAR 690-310-130;
- c. **will not** or **will** likely to be available within the capacity of the groundwater resource; or
- d. **will, if properly conditioned**, avoid injury to existing groundwater rights or to the groundwater resource:
 - i. The permit should contain condition #(s) 7C, 7J, medium water use reporting;
 - ii. The permit should be conditioned as indicated in item 2 below.
 - iii. The permit should contain special condition(s) as indicated in item 3 below;

- B2. a. **Condition** to allow groundwater production from no deeper than _____ ft. below land surface;
- b. **Condition** to allow groundwater production from no shallower than _____ ft. below land surface;
- c. **Condition** to allow groundwater production only from the _____ groundwater reservoir between approximately _____ ft. and _____ ft. below land surface;
- d. **Well reconstruction** is necessary to accomplish one or more of the above conditions. The problems that are likely to occur with this use and without reconstructing are cited below. Without reconstruction, I recommend withholding issuance of the permit until evidence of well reconstruction is filed with the Department and approved by the Groundwater Section.

Describe injury –as related to water availability– that is likely to occur without well reconstruction (interference w/ senior water rights, not within the capacity of the resource, etc): _____

B3. **Groundwater availability remarks:** The applicant’s well would access an aquifer hosted in secondary fractures and joints in granodiorite of the intrusive Wimer Pluton. Fractured rock aquifers typically have shallow water levels that mimic surface topography. Yields typically decrease with depths beyond 200-300 feet as fracture extent/interconnection decreases. Nearby wells JACK 64773, JACK 64774, and JACK 64775 indicate shallow water levels (10-20 feet) and yields varying from 2-60 gpm depending on the permeability of the fracture zone encountered. There are few water level observations over time from wells nearby, so over-appropriation cannot be determined at this time.

Because of the size of the applicant’s tax lot, there are no senior groundwater users within 1000 feet of the proposed POA. Considering the distance to adjacent wells, the low requested rate, and the presence of a nearby stream, there is a low probability that the requested use would cause well-to-well interference to the extent that would be considered injury to adjacent senior groundwater users.

C. GROUNDWATER/SURFACE WATER CONSIDERATIONS, OAR 690-09-040

C1. **690-09-040 (1):** Evaluation of aquifer confinement:

Well	Aquifer or Proposed Aquifer	Confined	Unconfined
1	Fractured Bedrock of Wimer Pluton	<input type="checkbox"/>	<input checked="" type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>

Basis for aquifer confinement evaluation: In fractured-bedrock aquifer systems, water is stored and transmitted primarily by discrete but connected fracture sets. These fractures generally extend to near the surface, so water within these fractures is likely under atmospheric pressure (unconfined) despite an overall low storage coefficient for the aquifer system as a whole and static water levels often reported above water-bearing zones on driller’s logs.

C2. **690-09-040 (2) (3):** Evaluation of distance to, and hydraulic connection with, surface water sources. All wells located a horizontal distance less than ¼ mile from a surface water source that produce water from an unconfined aquifer shall be assumed to be hydraulically connected to the surface water source. Include in this table any streams located beyond one mile that are evaluated for PSI.

Well	SW #	Surface Water Name	GW Elev ft msl	SW Elev ft msl	Distance (ft)	Hydraulically Connected?			Potential for Subst. Interfer. Assumed?	
						YES	NO	ASSUMED	YES	NO
1	1	Pleasant Creek	1520-1530	1438	560	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Basis for aquifer hydraulic connection evaluation: Groundwater levels in fractured rock aquifers are typically shallow. The high relief topography surrounding the applicant’s well creates a hydraulic gradient for groundwater to flow towards and discharge to surface water. The applicant’s well would access an unconfined aquifer and is located within ¼ mile of Pleasant Creek. As per OAR 690-009-0040(2), the well is assumed to be hydraulically connected to Thompson Creek.

Water Availability Basin the well(s) are located within: PLEASANT CR > EVANS CR - AB COLLINS CR

C3a. **690-09-040 (4):** Evaluation of stream impacts for each well that has been determined or assumed to be **hydraulically connected and less than 1 mile** from a surface water (SW) source. Limit evaluation to instream rights and minimum stream flows that are pertinent to that SW source, not lower SW sources to which the stream under evaluation is tributary. Compare the requested rate against the 1% of 80% *natural* flow for the pertinent Water Availability Basin (WAB). If Q is not distributed by well, use full rate for each well. Any checked box indicates the well is assumed to have the potential to cause PSI.

Well	SW #	Well < ¼ mile?	Qw > 5 cfs?	Instream Water Right ID	Instream Water Right Q (cfs)	Qw > 1% ISWR?	80% Natural Flow (cfs)	Qw > 1% of 80% Natural Flow?	Interference @ 30 days (%)	Potential for Subst. Interfer. Assumed?
1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	IS71013	0.52	<input checked="" type="checkbox"/>	0.35	<input checked="" type="checkbox"/>	>25	<input checked="" type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>

C3b. **690-09-040 (4):** Evaluation of stream impacts by total appropriation for all wells determined or assumed to be **hydraulically connected and less than 1 mile** from a surface water source. **Complete only if Q is distributed among wells.** Otherwise same evaluation and limitations apply as in C3a above.

SW #	Qw > 5 cfs?	Instream Water Right ID	Instream Water Right Q (cfs)	Qw > 1% ISWR?	80% Natural Flow (cfs)	Qw > 1% of 80% Natural Flow?	Interference @ 30 days (%)	Potential for Subst. Interfer. Assumed?
	<input type="checkbox"/>			<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>
	<input type="checkbox"/>			<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>

Comments: Stream depletion is estimated using the Hunt (1999) model using aquifer parameters representative of bulk aquifer properties in a fractured-intrusive hydrogeologic setting.

C4a. **690-09-040 (5):** Estimated impacts on **hydraulically connected surface water sources greater than one mile** as a percentage of the proposed pumping rate. Limit evaluation to the effects that will occur up to one year after pumping begins. This table encompasses the considerations required by 09-040 (5)(a), (b), (c) and (d), which are not included on this form. Use additional sheets if calculated flows from more than one WAB are required.

Non-Distributed Wells													
Well	SW#	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		%	%	%	%	%	%	%	%	%	%	%	%
Well Q as CFS													
Interference CFS													
(A) = Total Interf.													
(B) = 80 % Nat. Q													
(C) = 1 % Nat. Q													
(D) = (A) > (C)		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
(E) = (A / B) x 100		%	%	%	%	%	%	%	%	%	%	%	%

(A) = total interference as CFS; (B) = WAB calculated natural flow at 80% exceed. as CFS; (C) = 1% of calculated natural flow at 80% exceed. as CFS; (D) = highlight the checkmark for each month where (A) is greater than (C); (E) = total interference divided by 80% flow as percentage.

Basis for impact evaluation: Streams beyond 1 mile were not considered in this review.

C4b. **690-09-040 (5) (b) The potential to impair or detrimentally affect the public interest is to be determined by the Water Rights Section.**

- C5. **If properly conditioned**, the surface water source(s) can be adequately protected from interference, and/or groundwater use under this permit can be regulated if it is found to substantially interfere with surface water:
- i. The permit should contain condition #(s) _____;
 - ii. The permit should contain special condition(s) as indicated in "Remarks" below;

C6. **SW / GW Remarks and Conditions:** The applicant's well accesses an aquifer that is determined to be hydraulically connected to Pleasant Creek. The proposed use is found to have the Potential for Substantial Interference (PSI) with Pleasant Creek by the following metrics as outlined in OAR 690-009: the well is located within ¼ mile of a surface water source, the requested rate (0.056 cfs) is larger than 1% of the expected natural stream flow (1% of 0.35 cfs or 0.0035 cfs), the requested rate (0.056 cfs) is larger than 1% of adopted instream flow (1% of 0.52 cfs or 0.0052 cfs), and the estimated stream depletion after 30 days is greater than 25%. A lower rate will not avoid a finding of PSI. Additionally, there are several recently constructed water wells on the applicant's property. It is noted that all of these wells appear to be located within ¼ mile of Pleasant Creek.

References Used:

Hunt, B. 1999. Unsteady stream depletion from ground water pumping. Ground Water 37, no. 1: 98-102.

OWRD Groundwater Information System Database – Accessed 7/14/2021.

Theis, C.V., 1935. The relation between the lowering of the piezometric surface and the rate and duration of discharge of a well using groundwater storage. Am. Geophys. Union Trans., vol. 16, pp. 519-524.

Wiley, T.J., 2006, Preliminary geologic map of the Wimer and McConville Peak 7.5' quadrangles, Jackson and Josephine Counties, Oregon: Oregon Department of Geology and Mineral Industries, Open-File Report O-06-05, scale 1:24,000

D. WELL CONSTRUCTION, OAR 690-200

D1. Well #: _____ Logid: _____

D2. **THE WELL does not appear to meet current well construction standards based upon:**

- a. review of the well log;
- b. field inspection by _____;
- c. report of CWRE _____;
- d. other: (specify) _____

D3. **THE WELL construction deficiency or other comment is described as follows:** _____

D4. Route to the Well Construction and Compliance Section for a review of existing well construction.

Water Availability Tables

Water Availability Analysis

Detailed Reports

PLEASANT CR > EVANS CR - AB COLLINS CR
 ROGUE BASIN

Water Availability as of 7/14/2021

Watershed ID #: 71013 ([Map](#))

Exceedance Level: 80% ▾

Date: 7/14/2021

Time: 6:00 AM


Water Availability Calculation	Consumptive Uses and Storages	Instream Flow Requirements	Reservations
Water Rights	Watershed Characteristics		

Water Availability Calculation


Monthly Streamflow in Cubic Feet per Second
 Annual Volume at 50% Exceedance in Acre-Feet

Month	Natural Stream Flow	Consumptive Uses and Storages	Expected Stream Flow	Reserved Stream Flow	Instream Flow Requirement	Net Water Available
JAN	11.30	0.00	11.30	0.00	33.30	-22.00
FEB	20.10	0.00	20.10	0.00	34.00	-13.90
MAR	17.80	0.00	17.80	0.00	34.00	-16.20
APR	8.73	0.00	8.73	0.00	19.10	-10.40
MAY	3.91	0.00	3.91	0.00	7.01	-3.10
JUN	1.68	0.00	1.68	0.00	3.01	-1.33
JUL	0.74	0.00	0.74	0.00	1.02	-0.28
AUG	0.49	0.00	0.49	0.00	0.63	-0.14
SEP	0.35	0.00	0.35	0.00	0.52	-0.17
OCT	0.57	0.00	0.57	0.00	1.07	-0.50
NOV	1.92	0.00	1.92	0.00	5.43	-3.51
DEC	6.18	0.00	6.18	0.00	27.70	-21.50
ANN	10,700.00	0.00	10,700.00	0.00	10,000.00	673.00

Well Location Map



Water-Level Measurements in Nearby Wells



Stream Depletion Modeling Parameters and Results (Hunt, 1999)

Application type:	G
Application number:	19055
Well number:	1
Stream Number:	1
Pumping rate (cfs):	0.056
Pumping duration (days):	244.0
Pumping start month number (3=March)	1

Parameter	Symbol	Scenario 1	Scenario 2	Scenario 3	Units
Distance from well to stream	a	560	560	560	ft
Aquifer transmissivity	T	100	320	1000	ft ² /day
Aquifer storativity	S	0.001	0.0001	0.00001	-
Aquitard vertical hydraulic conductivity	Kva	0.01	0.05	0.1	ft/day
Not used		1	1	1	
Aquitard thickness below stream	babs	20	10	5	ft
Not used		1	1	1	
Stream width	ws	25	25	25	ft

Stream depletion for Scenario 2:

Days	10	30	60	90	120	150	180	210	240	270	300	330	360
Depletion (%)	56	71	78	82	84	86	87	88	89	20	12	9	7
Depletion (cfs)	0.03	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.01	0.01	0.00	0.00

