well "A"

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED JAN 03 1964 STATE ENGINEER

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

Apr Hbrw 1786
G 2225

State Well No. 37/36-24G
State Permit No. G-2056

(1) OWNER:
Name Whitehouse Ranch Inc
Address Andrews, Oregon

(2) LOCATION OF WELL:
Owners well #2
County Harney Driller's well number #6
SW ¼ NE ¼ Section 24 T. 37S R. 36E W.M.
Bearing and distance from section or subdivision corner
South 31 Degrees 00' West 29055 ft from the NE. Sec. Corner of Sec. 24 and it is the SW¼ NE¼ Sec. 24 T. 37S. R. 36 E. W.M. Oregon

(3) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:
Threaded [ ] Welded [X]
20" Diam. from 0 ft. to 20 ft. Gage 1/4"
18" Diam. from 0 ft. to 27 ft. Gage 3/16"
16" Diam. from 0 ft. to 237 ft. Gage 3/16

(7) PERFORATIONS:
Perforated? [ ] Yes [X] No
Type of perforator used
Size of perforations in by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed [ ] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 20' ft. Was a packer used? no
Diameter of well bore to bottom of seal 24" in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [ ] Yes [X] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

RECEIVED APR 10 1964 WATER RESOURCES DEPT. SALEM, OREGON

(10) WATER LEVELS:
Static level 125 ft. below land surface Date 4/15-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test none gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:
Diameter of well below casing 16"
Depth drilled 1100 ft. Depth of completed well 1100 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay & Gravel - Brown Soft	0	15
Gravel & Small Boulders	15	35
Clay - Sandy - Yellow Soft	35	170
Sand & Gravel	170	180
Clay Sandy w/streaks of Rock		
Grey - Soft	180	220
Lava - Grey - Hd	220	255
Lava w/streaks of Brown Sandy Clay -	255	310
Clay - Sandy - Yellow	310	350
Clay - Blue - Sticky	350	377
Lava Hd Grey	377	430
Basalt Hd. Black	430	439
Rock - Red - Hd	439	445
Rock - Red - Sandy Soft	445	540
Rock Grey - Soft Sandy	540	620
Sandy Rock - Red - w/streaks		
Clay	620	785
Shale Blue & Yellow	785	815
Sandy Rock - Crystaline		
Conglomerate Colors		
Med Hd	815	1100

Work started 3/4 1963 Completed 4/15 1963
Date well drilling machine moved off of well 4/26 1963

(13) PUMP:
Manufacturer's Name None
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME C & B Drilling Co.
(Person, firm or corporation) (Type or print)
Address P.O. Box 23, Crane, Oregon
Drilling Machine Operator's License No. 256
[Signed] H. C. Cunningham
(Water Well Contractor)
Contractor's License No. 271 Date , 19

(USE ADDITIONAL SHEETS IF NECESSARY)