



**Oregon**  
Kate Brown, Governor

**Water Resources Department**  
725 Summer St NE, Suite A  
Salem, OR 97301  
(503) 986-0900  
Fax (503) 986-0904

January 20, 2022

GW

CHRISTMAS VALLEY DOMESTIC WATER SUPPLY DISTRICT  
PO BOX 142  
CHRISTMAS VALLEY, OR 97641

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 12865	Permit: G 12659 *	LAKE0001021	LAKE0001021	11/19/2021	APPROVED		

Approved but test quality is poor. Average discharge rate decreased from 1,998 to 630 ft<sup>3</sup>/day during test (based on total volume readings).

Please contact me if you have any questions.

Sincerely,

*Jerry Grondin*

Jerry Grondin  
503-437-5348  
Groundwater Section

cc: GW Pump Test File  
cc: Certificates Section/Application File