

June 28, 2022

DENNIS COOK CLAREMONT GOLF CLUB INC. 15800 NW COUNTRY CLUB LANE PORTLAND, OR 97229

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	n Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 16157	Permit: G 15673 *	WASH0060848	WASH0060848	05/08/2019	APPROVED	None	A WELL (L-64521)
G 18856	Permit: G 18517 *	WASH0060848	WASH0060848	05/08/2019	APPROVED	Multiple Well	A WELL (L-64521)

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates that there are one or more deficiencies (listed below) related to the requirements for pump tests outlined in OAR 690-217, however; it is likely that any re-testing would constitute an unreasonable burden on the permittee and would provide data of only marginal value in satisfying the intent of the rules.

Initial pumping rate was not reported. This was resolved by contacting the pump contractor for an estimate. 0 However, initial variability in pumping rates can have a significant impact on interpreting aquifer parameters from pumping tests. Although this test is being approved for this well on the above listed permit(s), it is unlikely that the approval will carry forward onto any new permits or multiple-well exemption requests. If a new permit is issued for this particular well that requires a pump test or if you wish to request a multiple-well exemption on any other wells using this approved test, you may be denied and will need to perform a new test.

The following pump test related materials can be found on our web site at:

Pump test administrative rules: A booklet explaining pump tests: Pump test data forms: Multiple well exemption request:

https://secure.sos.state.or.us/oard/displayDivisionRules.action?selectedDivision=3186 https://www.oregon.gov/owrd/WRDFormsPDF/pump test.pdf https://www.oregon.gov/owrd/WRDFormsPDF/pump test coverF.pdf https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionform.pdf Unreas. burden exemption request: https://www.oregon.gov/owrd/WRDFormsPDF/pumptestexemptionunreasburden.pdf

Please contact me if you have any questions.

Sincerely,

Scandilla

Ben Scandella 503-437-5231 Groundwater Section

cc: GW Pump Test File cc: Certificates Section/Application File

GW