



Oregon
Kate Brown, Governor

Water Resources Department

725 Summer St NE, Suite A

Salem, OR 97301

(503) 986-0900

Fax (503) 986-0904

December 23, 2021

DOUGLAS & MARY JOHNSON
20900 S SPRINGWATER RD
ESTACADA, OR 97023

GW

The Department has reviewed the status of your pump test and any requests for extension(s) or exemption(s) for the following permitted well(s). The results are summarized in the following table:

Application	Water Right	Permitted Well	Pumped Well	Test Date	Request Status	Exemption	Well Name
G 18330	Permit: G 17935 *	CLAC0063378	CLAC0063378	03/15/2019	APPROVED	None	

Pump tests are intended to provide aquifer and well information for ground water resource characterization and to help solve well problems (OAR 690-217-0015(9)). A review of the test results indicates that there are one or more deficiencies (listed below) related to the requirements for pump tests outlined in OAR 690-217, however; it is likely that any re-testing would constitute an unreasonable burden on the permittee and would provide data of only marginal additional value in satisfying the intent of the rules.

- o Water levels measured to nearest half-foot instead of hundredth of a foot (OAR 690-217-0045(a))

Although this test is being approved for this well on the above listed permit(s), it is unlikely that the approval will carry forward onto any new permits or multiple-well exemption requests. If a new permit is issued for this particular well that requires a pump test or if you wish to request a multiple-well exemption on any other wells using this approved test, you may be denied and may need to perform a new test.

Please contact me if you have any questions.

Sincerely,

Halley Schibel

Halley Schibel

503-437-5233

Groundwater Section

cc: GW Pump Test File

cc: Certificates Section/Application File