STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

RECEIVED
JUL 8 1985
WATER RESOURCES DEPT
SALEM, OREGON

PLEASE TYPE or PRINT IN INK

Baker 1094

95/40E-16bc

(for official use only)

(1) OWNER:

Name L. J. S

Address

City Baker State OR.

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [ ]
Rotary Mud [ ] Dug [ ]
Cable [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Thermal: [ ] Withdrawal [ ] Reinjection [ ]
Other: Piezometric [ ] Grounding [ ] Test [ ]

(5) CASING INSTALLED:

Steel [X] Plastic [ ]
Threaded [ ] Welded [X]

6 " Diam. from +1½ ft. to 100 ft. Gauge .250

" Diam. from ft. to ft. Gauge

LINER INSTALLED:

Steel [ ] Plastic [ ]
Threaded [ ] Welded [ ]

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? [X] Yes [ ] No

Size of perforations 8 in. by ⅛ in.

45 perforations from 80 ft. to 100 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft.

Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " "

Air test 7 gal./min. with drill stem at 100 ft. 1 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [ ] No [X]

Well seal—Material used Cement Grout

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Amount of sealing material 8 sacks [X] pounds [ ]

How was cement grout placed? pump Thru pipe

Was pump installed? Type HP Depth ft.

Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.

Did any strata contain unusable water? [X] Yes [ ] No

Type of Water? Surface depth of strata 8'

Method of sealing strata off Cemented off

Was well gravel packed? [ ] Yes [X] No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Baker SW¼ NW¼ of Section 16 of

Township 9S (Township is North or South), Range 40E (Range is East or West), WM.

Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 80 ft.

Static level 25 ft. below land surface. Date

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 160 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	8	
Malium gravel	8	160	25

Date work started 6-11-85 /completed 6-14-85

Date well drilling machine moved off of well 6-14 1985

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Bill M Thompson Date 6-29, 1985

(bonded) Water Well Constructor Certification:

Bond 456118 (number) Issued by: Fidelity Deposit (Surety Company Name)

On behalf of Band Lobe (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Band Lobe (Water Well Constructor)

(Dated) 2 July 1985

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*46866-690