

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

RECEIVED
Bake 1141
WATER WELL REPORT
FEB 4 1975
STATE OF OREGON
STATE ENGINEER
SALEM, OREGON
(Please type or print)
(Do not write above this line)

RECEIVED

APR 26 1974

State Well No.

95/40 E-19

State Permit No.

(1) OWNER:

Name Allen Phillips
Address Rock Creek Road Baker Ore

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☐

6" Diam. from 0 ft. to 63 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? drilled
Yield: 16 gal./min. with 40 ft. drawdown after 2 hrs.

Bailer test no gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite
Well sealed from land surface to 26 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 3 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite

Number of pounds of bentonite per 100 gallons
of water I put it in dry lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☐ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Baker Driller's well number
NE 1/4 NE 1/4 Section 19 T. 9 S. R. 40 E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well:

Depth at which water was first found 56 1/2 ft. 58
Static level 18 ft. below land surface. Date
Artesian pressure 58 lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 63 ft. Depth of completed well 63 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil - black	0	9	
hard light clay	9	21	
clay and coarse gravel	21	36	
loam	36	41	
yellow clay	41	52	
gravel some water	52	55	
clay blue	55	58	
sand some gravel	58	63	
lots of water			

Work started B/12 1974 Completed 4/1 1974

Date well drilling machine moved off of well 4/4 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] A. W. Robinson Date 4/24, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 41

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name A. W. Robinson
(Person, firm or corporation) (Type or print)

Address 2809 1/2 9th St

[Signed] A. W. Robinson
(Water Well Contractor)

Contractor's License No. 128 Date 4/24, 1974