NC

RECEIVED
MAY 16 1966
STATE ENGINEER
SALEM, OREGON

RECEIVED
JUN 6 1966
STATE ENGINEER
SALEM, OREGON

Baker 1149

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 9/40-20
State Permit No.

(1) OWNER:
Name M V Bowman
Address 345 S Baker 3 Rivers Rt

(2) LOCATION OF WELL:
County Baker Driller's well number
¼ ¼ Section [redacted] T. 9 S R. 40 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:
Threaded [ ] Welded [X]
8" Diam. from 0 ft. to 19 ft. Gage
6" Diam. from 0 ft. to 40 ft. Gage .250
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? [ ] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 19 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 6 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off Bentonite

(10) WATER LEVELS:
Static level 7 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? Me
Yield: 8 gal./min. with 7 ft. drawdown after 6 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled ft. Depth of completed well 24 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
top soil	0	4
yellow clay	4	19
blue clay	19	39
coarse sand & water	39	40

Work started 3/24 19 66 Completed 3/29 19 66
Date well drilling machine moved off of well 3/28 19 66

(13) PUMP:
Manufacturer's Name Jacuzzi
Type: Jet H.P. 1/2

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A W Robinson (Person, firm or corporation) (Type or print)
Address 5809 97 Hwy Baker Ore
Drilling Machine Operator's License No. 41
[Signed] A W Robinson (Water Well Contractor)
Contractor's License No. 128 Date 4/30, 19 66

(USE ADDITIONAL SHEETS IF NECESSARY)