NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
MAR 02 1979
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Baker 1177

State Well No. 9S/40E-34d6
State Permit No.

(1) OWNER:
Name John Hill
Address S.R. Bo x 8 Pleasant Valley
Baker, Oregon 97814

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 70 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used torch
Size of perforations 1/8 in. by 6 in.
80 perforations from 20 ft. to 70 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☒ No If yes, by whom? Britton Equip.
Yield: 140 gal./min. with 16 ft. drawdown after 1 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed? poured
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 1/2" pea
Gravel placed from 18 ft. to 70 ft.

(10) LOCATION OF WELL:
County Baker Driller's well number
NW ¼ SE ¼ Section 34 T. 9S R. 40E W.M.
Bearing and distance from section or subdivision corner 300' east of property line and 200' south of county road

(11) WATER LEVEL: Completed well.
Depth at which water was first found 18 ft.
Static level 18 ft. below land surface. Date 9/16/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 70 ft. Depth of completed well 70 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	4	
Red Clay	4	18	
Rock and Sand	18	24	
Gray Cl ay	24	39	
Dark gray clay	39	52	
Light gray clay	52	70	

Work started 9/15 1978 Completed 9/21 1978
Date well drilling machine moved off of well 9/25 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Melvin L. Copley (Drilling Machine Operator) Date 9/29, 1978
Drilling Machine Operator's License No. 671

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Melvin L. Copley (Person, firm or corporation) (Type or print)
Address Box 27 Sumpter Stage Baker, Ore. 97814
[Signed] Melvin L. Copley (Water Well Contractor)
Contractor's License No. 536 Date 9/29, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119