

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

APR 22 1974

STATE ENGINEER
SALEM, OREGON

State Well No. 12S/37E-28
State Permit No.

*Baker
1455*

ba

(1) OWNER:

Name Oregon State Park (Unity)
Address % Roy Lesmeister Star Rt.
Forewell Bend, Huntington

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 1 ft. to 40 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 24 gal./min. with 6 ft. drawdown after 1 hrs.

Artesian flow g.p.m.
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 3 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Baker Driller's well number
N.E 1/4 N.W 1/4 Section 28 T. 12S R. 37E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 75 ft.
Static level 60 ft. below land surface. Date 4/15/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Gravelly Clay	0	10	
Med. to coarse gravel	10	35	
Yellow Clay	35	70	
Med. Fractured Sandstone	70	114	
Blue Clay	114	133	
Cavey Blue Clay	133	135	
Blue Clay	135	140	

Work started 4-10 1974 Completed 4-15 1974

Date well drilling machine moved off of well 4-16 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] *Winfield Page* Date 4-16, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 65

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name PAGE BROTHERS DRILLING
(Person, firm or corporation) (Type or print)

Address RT. 2- BOX 371 VALE OREGON 97918

[Signed] *Winfield Page*
(Water Well Contractor)

Contractor's License No. 564 Date 4-16, 1974