NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
MAY 10 1979
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

Baker 1533

State Well No. 14S/43E-11da
State Permit No.

(1) OWNER:
Name Keith McDaniels
Address Rt. 1 Box 26 Huntington, Ore. 97907

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) CASING INSTALLED:
Threaded [] Welded [X]
14 " Diam. from 0 ft. to 20 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 60 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 18 in.
Diameter of well bore below seal 14 in.
Number of sacks of ~~cement~~ used in well seal 12 sks. bentonite sacks
How was cement grout placed?
Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Baker Driller's well number #1
NE ¼ SE ¼ Section 11 T. 14S R. 43E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 23 ft.
Static level 30 ft. below land surface. Date 11/21/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 14
Depth drilled 231 ft. Depth of completed well 231 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil & clay, yellow	0	21	
Clay, blue	21	23	
1st water --23			23
Clay, blue	21	185	23
Gravel, small	185	195	30
Clay, hard & gravel	195	200	
Clay, light color, sand, gravel, small	200	225	30
Clay, hard, light green Soap-stone	225	231	

Work started 11/18 19 78 Completed 11/21 1978
Date well drilling machine moved off of well 11/21 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Glenn E. Hysell (Drilling Machine Operator) Date 11-24, 1978
Drilling Machine Operator's License No. 90

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Hysell Pumps & Drilling (Person, firm or corporation) (Type or print)
Address Box 351 Vale, Oregon 97918
[Signed] Glenn E. Hysell (Water Well Contractor)
Contractor's License No. 396 Date 11-24, 19 78

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*4565