

WATER WELL REPORT
STATE OF OREGON

Bake
210

RECEIVED

JUL 26 1985

WATER RESOURCES DEPT
SALEM, OREGON

State Well No. *75/46E-36da*

State Permit No.

(1) OWNER:

Name *Wayne C Hetwood*
Address
City *Halfway* State *OR*

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(10) LOCATION OF WELL:

County *BAKER* Driller's well number
NE $\frac{1}{4}$ SE $\frac{1}{4}$ Section *36* T. *7* R. *46E* W.M.
Tax Lot # Lot Blk Subdivision

Address at well location:

(11) WATER LEVEL: Completed well.

Depth at which water was first found *24* ft.
Static level *14* ft. below land surface. Date *6-27-85*
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing *6*

Depth drilled *60* ft. Depth of completed well *52* ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
GRAVEL LARGE	2	8	
BOULDERS	8	24	
GRAVEL SMALL	24	26	
GRAVEL LARGE	26	35	
GRAVEL MED - W/B	35	40	
SAND + GRAVEL	40	52	
GRAVEL MED - W/B	52	60	14

CASING INSTALLED:

Steel Plastic
Threaded Welded

6" Diam. from *7.2* ft. to *40* ft. Gauge *1.250*
....." Diam. from ft. to ft. Gauge

LINER INSTALLED:

....." Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

..... a pump test made? Yes No If yes, by whom?
id: gal./min. with ft. drawdown after hrs.
Air test *100* gal./min. with drill stem at *55* ft. *2* hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water *59* Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used *CEMENT*
Well sealed from land surface to *14* ft.
Diameter of well bore to bottom of seal *10* in.
Diameter of well bore below seal *6* in.
Number of sacks of cement used in well seal *3* sacks
How was cement grout placed? *GROUT PUMP*
Was pump installed? *NO* Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

Work started *6-17* 19*85* Completed *6-27* 19*85*
Date well drilling machine moved off of well *6-27* 19*85*

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] *Robert D. ...* Date *6-27*, 19*85*
(Drilling Machine Operator)

Drilling Machine Operator's License No.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name *K. DEANIS* (Type or print)
(Person, firm or corporation)
Address *SUMMITER STAGE BAKER OR*
[Signed] *Robert D. ...* (Water Well Contractor)
Contractor's License No. *591* Date *6-27*, 19*85*