



Oregon

Theodore R. Kulongoski, Governor

BAKE 51281

e✓10-19-04

Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1271
503-986-0900
FAX 503-986-0904

October 1, 2004

EARTH & WATER WORKS
JASON ACQUISTAPACE #1775
10202 S VALLEY AVE
ISLAND CITY OR 97850

FINAL ORDER

Dear Jason:

The Special Standard request you submitted for owner: Global Resource, Start Card number 165062, is approved for the following: Abandonment of a cased well in place. The well shall be cleaned out to the natural bottom and then filled with cement grout from the bottom of the well to the bottom of the casing (at approximately 79 feet bgs). From five feet below ground surface (bgs) to 79 feet bgs the well shall be filled with 5/8 inch unhydrated bentonite. Care shall be taken to minimize the introduction of bentonite dust into the sealing interval and a sounding or tamping tool shall be used to measure fill up rate and to break up possible bridges or cake formations. From five feet bgs to land surface the well shall be filled with cement grout. The well casing may then be severed below land surface and removed. See Oregon Administrative Rule (OAR) 690-220-0060. Your Special Standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, please contact me at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wr.d.state.or.us.

Sincerely,

Kristopher Byrd
Well Construction Program Coordinator
Enforcement Section

enclosure

cc: Bob Maynard, East Region Well Inspector
File

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137.004-0080 and OAR 690-01-0005 you may either petition for judicial review or petition the Director for reconsideration of this order.

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 158 12th Street NE, Salem OR 97301. Requests may also be considered by the appropriate Regional Manager.

Date of request: 10-1-04 Oral approval date (if applicable): 10-1-04

Bonded Well Constructor (name, license #, and mailing address): JASON ACQUISTAPACE
#1775 10202 S. VALLEY AVE ISLAND CITY 97850

(1) Location of Well: SE 1/4 NE 1/4 of Section 31,
Township 11S N/S, Range 42E E/W, BAKER County
Address at well site: 28089 BURNT RIVER CANYON

(2) Start Card Number(s)(for work to be done): 165062

(3) Name and Address of Land Owner: GLOBAL RESOURCE
PO BOX 891479 TEMICULLA, CA 92589

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
120' FROM SEPTIC TANK - LINES BEYOND

(5) The unusual site conditions which necessitate this request: THE 6" CASING
CANNOT BE PERFORATED WITH A
PERFORATOR - MILLS KNIFE


(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
SEAL THE UNCASSED PORTION WITH CEMENT
GROUT. THEN FILL THE CASING WITH
5/8" BENTONITE CHIPS TO 5'. CAP WELL
WITH 5' OF CEMENT TO THE SURFACE

RECEIVED

OCT 01 2004


WATER RESOURCES DEPT.
SALVAGE DIVISION

W
AP
Remarks: Abandon in place



- (1) **The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.**
- (2) **If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.**
- (3) **If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.**

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: 

BAKER 31281

FOR WATER RESOURCES DEPARTMENT USE ONLY

Date Postmarked _____
Date Hand-Delivered _____
Date Region Office Rec'd _____

W 165062
OWRD Receipt _____
Date Fee Received _____
Check No. _____

**START CARD
NOTICE OF BEGINNING OF WELL CONSTRUCTION
(as required by ORS 537.762)**

This form must be completed and the original mailed or delivered to the Water Resources Department, 725 Summer Street NE Suite A, Salem OR 97301-1271 for all new construction, conversion, alteration, deepening and abandonments. This original must be mailed or delivered before work is commenced. A \$125 fee shall accompany the original for all new well construction, conversion, and deepenings (make checks payable to the Water Resources Department). In addition, the constructor shall provide a legible copy of this notice to the region office within which the well is being constructed, converted, altered, deepened, or abandoned using one of the following methods: (a) by regular mail no later than three (3) calendar days (72 hours) prior to commencement of work; (b) by hand delivery, during regular office hours before work is commenced; or (c) by FAX before work is commenced. If method (c) is used, a legible copy of the start card shall also be mailed or delivered to the region office no later than the day work is commenced. The Water Resources Commission has authority to impose civil penalties for failure to submit the required \$125 fee with the start card, for failure to submit the \$125 fee in a timely manner, and for failure to timely submit start cards.

Owner's name and mailing address: LOST MINERS ASSO / GLOBAL RESOURCES
Home Phone: () P.O. Box 891479
Work Phone: (541) 519-0104 TEMICULLA, CA 99589

Type of work: Fee New Construction No Fee Alteration (Repair/Recondition)
Required: Conversion Required: Abandonment Orig. Start Card No. _____
 Deepening Orig. Start Card No. _____

Proposed Commencement Date: 10-12-04
Card No. _____

Existing or Proposed Well Depth: 92' Diameter: 6" Original Well I.D. Label Number: _____

Use: Domestic Community (Public System) Industrial Irrigation
 Thermal Injection Monitoring Other _____

Proposed Well Location:
County BAKER Township 11S Range 42E Section 31 Tax Lot 200
North or South East or West
1/4 SE 1/4 NE Or Latitude _____ Longitude _____

Street Address of well, if not assigned, nearest address:
28089 BURNT RIVER, DURKEE, OR 97905

We have read the back of this form and the information provided is accurate to the best of our knowledge.
Owner/Agent Name _____ Bonded Water Supply/Monitor Well Constructor Name _____ License No. 1775
Date Signed _____ Company EARTH + WATER WORKS, INC. Date Signed 10-1-04

OWNER PLEASE NOTE: This is not a water right application. The owner is responsible for obtaining a water right through the Water Resources Department, if required. The Oregon Health Division requires plans to be submitted and approved prior to construction if the well is to be used as a public system.
ADDITIONAL IMPORTANT INFORMATION ON BACK.
