

RECEIVED

Baker 629

WATER WELL REPORT

8/40-276

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER SALEM, OREGON

STATE OF OREGON

G-2261

State Well No.

State Permit No.

G-2077

(1) OWNER:

Name Wm. Schaan
Address 1400 2nd St.
Baker, Oregon

(2) LOCATION OF WELL:

County Baker Owner's number, if any--
S. W. 1/4 N. E. 1/4 Section 27 T. 8 S. R. 40 E. W.M.
Bearing and distance from section or subdivision corner 1,980 ft. W
on the south boundary of section 27, thence due
N 2,670 ft from the S. E. corner of section 27,
to the site of the well.

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
Abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [ ]

16 " Diam. from 0 ft. to 40 ft. Gage 1/4 "
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No

Type of perforator used acetylene torch
SIZE of perforations 12 in. by 3/8 in.
perforations from 0 ft. to 40 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed [ ] Yes [X] No

Manufacturer's Name None
Type Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [ ] Yes [X] No To what depth? ft.
Material used in seal--
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? soft Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 11/1/61
Artesian pressure lbs. per square inch Date

Log Accepted by
Wm Schaan Date 2/15, 1962
By Ken Khoultz

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [ ] No If yes, by whom? lifter Co.
Yield: 465 gal./min. with 28 ft. drawdown after 3 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysts made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well 16 inches.

Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Black top soil, Clay, Sand and Gravel, Yellow Clay, Water bearing coarse sand, Coarse sand and fine gravel.

Work started 10/20 1961. Completed 11/1/ 1961

(13) PUMP:

Manufacturer's Name Peerless Pump
Type: Turbige 12 " Bowls H.P. 20

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. W. Robinson (Person, firm, or corporation) (Type or print)

Address 3240 10th St., Baker, Oregon

Driller's well number

[Signed] A W Robinson (well Driller)

License No. 128 Date 2/15, 1962