

RECEIVED  
NOV - 1 1962  
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON

G 2596

State Well No. ....

State Permit No. ....

(1) OWNER:

Name Pine Eagle School District No. 61

Address P. O. Box 733

Halfway, Oregon

(2) LOCATION OF WELL:

County Baker Owner's number, if any—

1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner

Commencing 1540 feet East and 1320 feet South  
of the quarter corner common to Sections 7 & 8,  
in Township 8 South, Range 46 EWM, thence East  
10 feet; thence North 495 feet; thence West  
10 feet; thence South 495 feet to place of

beginning.

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐  
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐  
Cable ☒ Jetted ☐  
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒

1 1/2" Diam. from 0 ft. to 19 ft. Gage 250

1 1/2" Diam. from 0 ft. to 137 ft. Gage 250

9" Diam. from 0 ft. to 200 ft. Gage 250

(7) PERFORATIONS:

Perforated? ☐ Yes ☐ No

Type of perforator used

SIZE of perforations in. by in.  
12 X 3/8 perforations from 0 ft. to 200 ft.  
perforations from On 8" pipe ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Slot size Set from ft. to ft.

Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.

Material used in seal—

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? Depth of strata

Method of sealing strata off 1 1/2" solid pipe 19

(10) WATER LEVELS:

Static level 5' ft. below land surface Date 8/30-62

Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Chris L. Murray Date 10/30/, 1962.  
(Owner)

Sept.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Ballor test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 257 ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | FROM | TO |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|----|
| 0 to 6" top soil, 6" to 14 ft. a conglomerate, 14 ft. to 19' clay dry, 19' to 24' coarse sand some water; 24' to 30' guy clay; 30' to 34' coarse sand; 34' to 36', 36' to 42' coarse sand and fine gravel; 42' to 47' clay yellow; 47' to 54' clay dark yellow; 54' to 60' sand and gravel; 60' to 66' clay yellow; 66' to 72' gravel with some sand; 72' to 115' stones. I don't think any water; 115' to 150' rock clay and some water, I think. 150' to 157' to 165' clay with large stones; 165' to 180' clay with rocks but some collar; 180' to 198' soft clay; 198 to 200' solid rock with cracks in it; 240' to 246' yellow clay; 246' to 257' solid rock bottom, coarse gravel. |      |    |

Work started July 19 62 Completed October 19 62

(13) PUMP:

Manufacturer's Name

Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. W. Robinson  
(Person, firm, or corporation) (Type or print)

Address 3270-17th NW Baker Ore

Driller's well number

[Signed] A. W. Robinson  
(Well Driller)

License No. 128 Date 10/26, 1962