

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

State Well No. 8/4⁶-218
 State Permit No. _____

(1) OWNER:
 Name HALF WAY SAWMILL - Elling Jm Lbr Co.
 Address HALF WAY OREGON
DON ELLINGSEN MGR. BAKER ORE

(2) LOCATION OF WELL:
 County Baker Driller's well number _____
NW 1/4 NE 1/4 Section 21 T. 8-S R. 47E W.M.
 Bearing and distance from section or subdivision corner
LOCATED 50' NORTH & 100' EAST
7 SAWDUST BURNER.

TYPE OF WORK (check):

Drill Deepening Reconditioning Abandon
 Adornment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
1.2" Diam. from -1 ft. to 134 ft. Gage 1/4
1.0" Diam. from 127 ft. to 307 ft. Gage 1/4
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used STAR DRIVE DOWN
 Size of perforations _____ in. by _____ in.
4993 perforations from 30 ft. to 134 ft.
0 perforations from _____ ft. to _____ ft.
0 perforations from 127' ft. to 307' ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal CEMENT
 Depth of seal 20 ft. Was a packer used? SAND
 Diameter of well bore to bottom of seal 2.0 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 20 ft. below land surface Date 9-11-65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? DRILLER
 Yield: 590 gal./min. with 130 ft. drawdown after 8 hrs.
 " " " " " "
 " " " " " "
 " " " " " "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 57° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing NONE
 Depth drilled 307 ft. Depth of completed well 307 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY & Boulders	0	20
CLAY & GRAVEL Some water	20	30
GRAVEL MEDIUM WATER	30	47
CLAY BROWN	47	69
GRAVEL Some clay water	69	93
CLAY BROWN No water	93	100
GRAVEL MEDIUM WATER	100	113
CLAY GRAVEL Embedded	113	126
GRAVEL SAND Some water	126	132
CLAY THIN GRAVEL STREAK	132	197
CLAY BROWN	197	247
GRAVEL MEDIUM WATER	247	254
CLAY BROWN	254	268
GRAVEL STREAK WATER	268	271
CLAY BROWN	271	295
GRAVEL MEDIUM WATER	295	298
CLAY BROWN	298	301
GRAVEL MEDIUM WATER	301	305
CLAY BROWN	305	306
GRAVEL MEDIUM WATER	306	307

Work started 8-9 1965 Completed 9-11 1965
 Date well drilling machine moved off of well 9-14 1965

(13) PUMP: Manufacturer's Name Peerless
 Type: TURBINE H.P. 70

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME HOLLOWAY DRILLING Co
 Address ONTARIO OREGON
 Drilling Machine Operator's License No. 101
 [Signed] Max Holloway
 Contractor's License No. 16 Date 9-30 1965