

WATER WELL DRILLERS REPORT
STATE OF OREGON

Do Not File In State Well No. 7/39-7J
State Permit No. 128 G2473

Baker 83

(1) OWNER:
Name W.C. McCall 2710 SB-50th
Address Portland, Oregon

(2) LOCATION OF WELL:
County BAKER Owner's number, if any—
R. F. D. or Street No.
Bearing and distance from section or subdivision corner
1685' N; 1150' W. SE COR SEC. 7, T. 75R. 39 EWM
NE 4 SE 4 Sec. 7, T. 75 R. 39 EWM

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Agricultural Industrial Municipal
Irrigation Test Well Other
(5) EQUIPMENT:
Rotary
Cable
Dug Well

(6) CASING INSTALLED:
Threaded Welded

FROM	ft. to	ft.	Diam.	Gage or Wall	Diameter of Bore	from ft.	to ft.
"	0	147 1/2	12	3/8			
"	"	"	"	"			
"	"	"	"	"			
"	"	"	"	"			

If gravel packed
Type and size of shoe or well ring steel Size of gravel:
Describe joint welded

(7) PERFORATIONS:
Type of perforator used

TYPE	of perforations	in., length, by	in.	
DM	ft. to	ft.	perf per foot	No. of rows
"	0	147 1/2	3/16	6
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"

SCREENS:
Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION:
Was a surface sanitary seal provided? Yes No To what depth ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata
FROM ft. to ft.

METHOD OF SEALING

(9) WATER LEVELS:
Depth at which water was first found 30 ft.
Standing level before perforating ft.
Standing level after perforating 9 ft.
Log Accepted by:
[Signed] _____ Dated _____, 19____
Owner

(10) WELL TESTS: *Baker Drilling*
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. draw down after hrs.
" 1000 " 80 " 16 "
" " " " "
Artesian flow 710 g.p.m.
Shut-in pressure lbs. per square inch.
Bailer test g.p.m. with ft. drawdown
Temperature of water 56 Was a chemical analysis made? Yes No
Was electric log made of well? Yes No *air*

(11) WELL LOG:
Diameter of well, 11 inches.
Total depth 150 ft. Depth of completed well 150 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
ft. to
0-5 black top soil
5-33 light colored soil of clay & sand at 35-30/2
to 60 sand & fine gravel
60 to 75 sand & gravel. 75
to 100 coarse sand, 100
to 150 fine sand at
bottom coarse gravel
" " "
" " "
" " "
" " "
" " "
" " "
" " "
" " "
" " "
" " "

Ground elevation at well site feet above mean sea level.
Work started 19 Completed 19

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME A W Robinson
(Person, firm, or corporation) (Typed or printed)
Address 3240 - 10th St
Driller's well number
[Signed] A W Robinson
(Well Driller)
License No. 128 Dated Mar 7, 1956