

*Baker 88*

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

**RECEIVED**  
JAN 26 1966

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion

STATE OF OREGON (Please type or print)

State Well No. 7/39-14 P  
State Permit No. \_\_\_\_\_

(1) OWNER: SALEM OREGON

Name Bill Brace  
Address Haines, Oregon

(2) LOCATION OF WELL:

County Baker Driller's well number 43  
SE 1/4 NW 1/4 Section 14 T. 7s R. 39E W.M.  
Bearing and distance from section or subdivision corner  
700' W 500' N of the SE corner  
of SE 1/4 of the SW 1/4 of Sec. 14 T 7  
R 39 E

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
16" Diam. from 0 ft. to 487 ft. Gage .312  
12" Diam. from 463 ft. to 490 ft. Gage .250  
....." Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Mills Knife & Torch  
Size of perforations 1/2 in. by 3 in.  
1,300 perforations from 146 ft. to 480 ft.  
850 perforations from 570 ft. to 585 ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name ..... Model No. ....  
..... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Grout  
Depth of seal 18 ft. Was a packer used? sand  
Diameter of well bore to bottom of seal 20 in.  
Were any loose strata cemented off?  Yes  No Depth .....

(10) WATER LEVELS:

Static level 46' ft. below land surface Date 10/10/65  
Artesian pressure lbs. per square inch Date .....

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: 460 gal./min. with 100 ft. drawdown after 6 hrs.  
" 500 " 128 " 10 "  
" 560 " 190 " 24 "

Baller test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 53 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 600 ft. Depth of completed well 600 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay Sandy (brown) soft	0	22
Clay Sandy (yellow) soft	22	48
Sandstone (brown) soft	48	74
Conglomerate Red soft	74	133
Conglomerate Brown soft	133	164
Clay & Gravel Brown Sticky	164	176
Conglomerate Brown hard	176	297
Clay & Gravel Yellow Sticky	297	318
Conglomerate Brown soft	318	416
Clay Sandy hard with granite	416	486
Sandstone yellow hard	486	526
Clay Sandy yellow	526	552
Clay Sandy yellow & pea gr.	552	590
Decomposed Granite	590	600

Work started 8/17/65 19 Completed 10/10/65 19

Date well drilling machine moved off of well 10/10/65 19

(13) PUMP:

Manufacturer's Name None  
Type: ..... H.P. ....

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Stoffel Bros. Drilling Co.  
(Person, firm or corporation) (Type or print)

Address Rt 2 Box 78 La Grande, Oregon

Drilling Machine Operator's License No. 349

[Signed] Robert J. Stoffel  
(Water Well Contractor)

Contractor's License No. 415 Date 12/29/65, 19...