

RECEIVED

APR 2 1984

95/39E-13CA

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

Baker 932

PLEASE TYPE or PRINT IN INK WATER RESOURCES DEPT. (for official use only)

SALEM, OREGON

(1) OWNER:

Name Dan Warnock Jr. Address West Campbell St. City Baker, O State Oregon

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary Air [ ] Driven [ ] Domestic [x] Industrial [ ] Municipal [ ] Thermal [ ] Rotary Mud [ ] Dug [ ] Irrigation [ ] Withdrawal [ ] Reinjection [ ] Other: [x] Bored [ ] Piezometric [ ] Grounding [ ] Test [ ]

(5) CASING INSTALLED: Steel [ ] Plastic [ ] Threaded [ ] Welded [x] 8" Diam. from 0 ft. to 115 ft. Gauge 250

LINER INSTALLED: Steel [ ] Plastic [ ] Threaded [ ] Welded [ ] " Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? [x] Yes [ ] No Size of perforations 1/8 in. by 6 in. 80 perforations from 100 ft. to 115 ft.

(7) SCREENS: Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? same 20 gal./min. with 80 ft. drawdown after 2 hrs.

(9) CONSTRUCTION: Special standards: Yes [ ] No [x] Well seal—Material used Cement Well sealed from land surface to 19 ft. Diameter of well bore to bottom of seal 12 in. Diameter of well bore below seal 8 in. Amount of sealing material 11 sacks [x] pounds [ ] How was cement grout placed? Centrifugal pump Was pump installed? No Type HP Depth ft. Was a drive shoe used? [x] Yes [ ] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [x] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Baker NE 1/4 SW 1/4 of Section 13 Township 9S Range 39E WM.

Mailing Address of Well (or nearest address) West Campbell St. Well located 800' SW of center of Sec 13 T9S R39E in NE 1/4 of SW 1/4

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 30 ft. Static level 30 ft. below land surface. Date Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8" Depth drilled 115 ft. Depth of completed well 115 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Sandy Clay, Brown Clay, Blue Clay, Small Gravel, Gray Clay, Blue Clay, Medium Gravel.

Date work started 6-20-77 / completed 6-29-77 Date well drilling machine moved off of well 6-30- 19 77

(unbonded) Water Well Constructor Certification (if applicable): This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Melvin L. Copley Date 7/15, 19 77

(bonded) Water Well Constructor Certification: Bond 458 262 Issued by: United Pacific Ins. Co. On behalf of Melvin L. Copley

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Melvin L. Copley (Water Well Constructor)

(Dated) Copied From Log dated 7-25-77

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP\*46866-690