

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
MAY 17 1965

WATER WELL REPORT

STATE OF OREGON  
(Type or print)

STATE ENGINEER

SALEM, OREGON

*Bake*  
*971*

State Well No.

*9/40-3 N*

State Permit No.

(1) OWNER:

Name *John Leonard*  
Address *Baker Oregon*

(2) LOCATION OF WELL:

County *Baker* Driller's well number  
*SW 1/4 SW 1/4 Section 3 T. 9 S. R. 40 E W.M.*  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐  
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐  
Cable ☒ Jetted ☐  
Dug ☒ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☐  
*10"* Diam. from *0* ft. to *10* ft. Gage *288*  
*8"* Diam. from *0* ft. to *33* ft. Gage *1288*  
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations	in.	by	in.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
In. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal *Bennett*  
Depth of seal *48* ft. Was a packer used? *72*  
Diameter of well bore to bottom of seal *10* in.  
Were any loose strata cemented off? ☐ Yes ☐ No Depth  
Was a drive shoe used? ☒ Yes ☐ No  
Was well gravel packed? ☐ Yes ☒ No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water? ☐ Yes ☒ No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level *8* ft. below land surface Date *5/4/65*  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? *Owner*

Yield: *don't know but satisfied* gal./min. with ft. drawdown after hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing

Depth drilled ft. Depth of completed well ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<i>top soil left</i>	<i>0</i>	<i>6</i>
<i>18 ft had been dug by hand some time ago it looked like gravel and clay</i>		
<i>below 18 ft mostly sand and gravel with streaks of clay</i>	<i>18</i>	<i>34</i>
<i>gravel cone at bottom</i>		

Work started *4/8* 19 *65* Completed *4/20* 19 *65*  
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name *Johnson*  
Type: *Centrifugal* H.P. *5*

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME *A W Robinson*  
(Person, firm or corporation) (Type or print)

Address *6809 9th St Baker Ore*

Drilling Machine Operator's License No. *41*

[Signed] *A W Robinson*  
(Water Well Contractor)

Contractor's License No. *128* Date *5/6* 19 *65*