

RECEIVED

702

Bake 980

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

JUL 12 1966 WATER WELL REPORT

State Well No. 9/40-4K

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER OF OREGON (Please type or print)

G-3764

State Permit No.

(1) OWNER:

Name W.M. Woodman
Address Box 142 Baker Oregon

(2) LOCATION OF WELL:

County Baker OR Driller's well number 2 E
Section 4 T. 9 S. R. 40 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

16" Diam. from 0 ft. to 19 ft. Gage 250
12" Diam. from 0 ft. to 50 ft. Gage 230

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Torch
Size of perforations 12 in. by 3/8 in.
1 1/2" perforations from 19 ft. to 50 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement grout
Depth of seal ft. Was a packer used?
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata

(10) WATER LEVELS:

Static level 3 ft. below land surface Date
Artesian pressure 20 lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Owner
Yield: 600 gal./min. with 17 ft. drawdown after 6 hrs.

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled ft. Depth of completed well 50 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include: Top soil (0-7), Clay yellow (7-19), 1/2" coarse matter (19-36), Clay gray (36-40), Coarse sand gravel (40-50)

Work started May 30 1966 Completed June 11 1966
Date well drilling machine moved off of well June 12 1966

(13) PUMP:

Manufacturer's Name Peerless
Type: Shallow Well H.P. Tractor

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A.W. Robinson (Person, firm or corporation)
Address 2009 1/2 9th St Baker Ore
Drilling Machine Operator's License No. 41
[Signed] A.W. Robinson (Water Well Contractor)
Contractor's License No. 128 Date June 14 1966