NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 16 1969 STATE ENGINEER SALEM, OREGON

Bent 1568

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JUN 26 1969 STATE ENGINEER SALEM, OREGON

State Well No. 10/3W-31
State Permit No.

(1) OWNER:
Name ROBERT D. BEHYMER
Address 1120 SHADY LANE ALBANY

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
8" Diam. from 0 ft. to 27 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used TORCH
Size of perforations 3 in. by 1/4 in.
16 perforations from 24 ft. to 27 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 14 ft. below land surface Date 5/3/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 20 gal./min. with 4 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 48° Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used Quick jel
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County BENTON Driller's well number 69-12
¼ ¼ Section 31 T. 10S R. 3W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 33 ft. Depth of completed well 33 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Clay	0	8	
Brown Sandstone	8	21	
Gravel And Black Sand	21	33	14

Work started 5/29 1969 Completed 6/3 1969
Date well drilling machine moved off of well 6/4 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ralph Lange (Drilling Machine Operator) Date 6/11, 1969
Drilling Machine Operator's License No. 571

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME VALLEY WELL DRILLERS (Person, firm or corporation) (Type or print)
Address P.O. BOX 885 ALBANY, OREGON
[Signed] Edward Butts (Water Well Contractor)
Contractor's License No. 753 Date 6-11, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)