

G-4655 ?
10/3w-31Q ?

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 10/3w-31
State Permit No. _____

RECEIVED
JUN 16 1965
STATE ENGINEER

Bent
1610

(1) OWNER: SALEM OREGON

Name Tripp & Tripp
Address 206 W. 1st Ave.
Albany, Oregon

(2) LOCATION OF WELL:

County Benton Driller's well number
1/4 Section 31 T. 10S R. 3W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded

8 " Diam. from 0 ft. to 39 ft. Gage 17#

(7) PERFORATIONS: Perforated? Yes No

Type of perforator used Acetylene Torch

Size of perforations 3/8 in. by 12 in.
20 perforations from 29 ft. to 39 ft.

(8) SCREENS: Well screen installed? Yes No

Manufacturer's Name _____
Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusuable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 22 ft. below land surface Date 6-7-65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Stettler Supp
Yield: 550 gal./min. with NO ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 8"

Depth drilled 50 ft. Depth of completed well 50 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Clay	3	19
Gravel	19	42
Clay & Gravel	42	45
Clay	45	50

Work started 6-1 1965. Completed 6-5 1965
Date well drilling machine moved off of well 6-5 1965

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Merle Warren Well Drilling (Person, firm or corporation) (Type of print)
Address Rt. 1, Box 85, Tangent, Oregon

Drilling Machine Operator's License No. 313
[Signed] Merle Warren (Water Well Contractor)
Contractor's License No. 182 Date 6/9, 1965