

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

*Bent  
1614*

**BENT 1614 RECEIVED**  
WATER WELL REPORT

*105/3W-31*

STATE OF OREGON  
(Please type or print) **MAR 10 1976**

State Well No. ....

(Do not write above this line)  
WATER RESOURCES DEPT.  
SALEM, OREGON

State Permit No. ....

(1) OWNER:  
Name Phyllis Vollstedt  
Address 451 Quarry Rd., Albany, Ore. 97321

(10) LOCATION OF WELL:  
County Benton Driller's well number  
31 T. 10SR. 3W W.M.  
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 25 ft.  
Static level 20'06" ft. below land surface. Date 10-16-75  
Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL: Rotary  Driven   
Cable  Jetted  Dug  Bored   
(4) PROPOSED USE (check): Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(12) WELL LOG: Diameter of well below casing 10"  
Depth drilled 50 ft. Depth of completed well 50 ft.  
Formation: Describe color, texture, grain size and structure of materials;  
and show thickness and nature of each stratum and aquifer penetrated,  
with at least one entry for each change of formation. Report each change in  
position of Static Water Level and indicate principal water-bearing strata.

CASING INSTALLED: Threaded  Welded   
10" Diam. from +1' ft. to 38 ft. Gage 250 Wall  
" Diam. from " ft. to " ft. Gage  
" Diam. from " ft. to " ft. Gage

MATERIAL	From	To	SWL
Top Soil	0	4	
Brown Sandy Clay	4	9	
Br. Sandy Clay & Grav.	9	17	
Dirty Br. Sand & Grav.	17	21	
Brown Sand & Gravel	21	36 1/2	
Soft Blue Sandstone	36 1/2	50	

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used Acetylene Torch  
Size of perforations 1/2 in. by 12 in.  
65 perforations from 27'06" ft. to 38 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from " ft. to " ft.  
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Self  
Yield: 350 gal./min. with 13 ft. drawdown after 3 hrs.  
" " " " " "  
" " " " " "  
Ballor test gal./min. with " ft. drawdown after " hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered " ft.

Work started 10-14 19 75 Completed 10-16 19 75  
Date well drilling machine moved off of well 10-16 19 75

(9) CONSTRUCTION:  
Well seal—Material used Cement  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 24 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 1 1/2 Yds. Concrete  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons  
of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision.  
Materials used and information reported above are true to my  
best knowledge and belief.  
[Signed] Marle Warren Date 10-20, 19 75  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 436

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is  
true to the best of my knowledge and belief.  
Name Marle Warren Well Drilling  
(Person, firm or corporation) (Type or print)  
Address Rt. 1, Box 84, Tangent, Ore. 97389  
[Signed] Marle Warren  
(Water Well Contractor)  
Contractor's License No. 182 Date 10-20, 19 75



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.wrd.state.or.us

Application for
Well ID Number

RECEIVED

AUG 28 2015

Do not complete if the well already has a Well Identification Number.

I. OWNER INFORMATION

WATER RESOURCES DEPT
SALEM, OREGON

Current Owner Name (please print): Linda Ann Sims
Mailing Address: 451 NW Quarry Rd
City, State, Zip: Albany OR 97321
Mail Well ID Tag to: [X] SAME AS ABOVE [ ] In Care Of (C/O) - picked up in person -
Name & Address:
City, State, Zip:

II. WELL LOCATION INFORMATION (Please fill out as completely as possible)

Township: 10 (North / South) Range: 3 (East / West) Section: 31
Tax Lot: 102 County Benton 1/4 1/4
GPS Coordinates:
Street Address of Well, City: 451 NW Quarry Rd, Albany 97321 (nearest)
If the property had a different street address in the past:

III. GENERAL WELL INFORMATION (Please fill out as completely as possible)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): Marked domestic, but used for irrigation
Date Well Constructed (or property built): 10-16-75 Total Well Depth: 50 Casing Diameter: 10
Owner at time the well was constructed (if known): Phyllis Vollstedt
Other Information: "Irrigation well"

SUBMITTED BY (please print): Linda Ann Sims
PHONE: 541-926-5640 EMAIL &/or FAX:

Send application to: Oregon Water Resources Department 725 Summer St NE, Suite A, Salem, Oregon 97301; or fax to (503) 986-0902. Applications are processed in the order they are received, and Well ID Numbers are mailed within 4-5 business days.

For Official Use Only by the Oregon Water Resources Department:

Received Date: 8-28-15

Well Log Number: BENT 1614

Well Identification #: L-119833

(In person)