

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion:

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print) (Do not write above this line)

*Bent  
1734*

State Well No. 10/4W-15

State Permit No. \_\_\_\_\_

RECORDED  
JAN 11 1968  
STATE ENGINEER  
OREGON

**(1) OWNER:**

Name Kenneth Holmes  
Address Rt. 4, Box 517, Albany, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded

10" Diam. from 1 ft. to 34 ft. above land surface to below land surface

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used Cutting torch  
Size of perforations 1/4 in. by 8 in.  
45 perforations from 25 ft. to 33 ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WATER LEVEL: Completed well.**

Static level 20 ft. below land surface Date 12/16/67  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
\_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Bailer test 30 gal./min. with 2 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 50° Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used heavy clay & bentonite  
Depth of seal \_\_\_\_\_ 18 ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ 14 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: 1/4" round  
Gravel placed from \_\_\_\_\_ 18 ft. to \_\_\_\_\_ 34 ft.

**(11) LOCATION OF WELL:**

County Benton Driller's well number \_\_\_\_\_  
1/4 Section 36 T. 10S R. 4 W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing -0-

Depth drilled 34 ft. Depth of completed well 34 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	1'	
Brown clay	1'	22'	
Med. gravel and coarse sand (water bearing)	22'	34'	20'

Work started Dec. 16, 19 67 Completed Dec. 19, 19 67  
Date well drilling machine moved off of well Dec. 19, 19 67

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Art Clinton Date 1/9/67, 19 \_\_\_\_\_  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 34

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ART CLINTON WELL DRILLING CO.  
(Person, firm or corporation) (Type or print)

Address Rt1, Box 2, Independence, Oregon 97351

[Signed] Art Clinton  
(Water Well Contractor)

Contractor's License No. 14 Date January 9, 1967