

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

OCT 12 1966 STATE OF OREGON
(Please type or print)

*Bent
1745*

State Well No. 10/46-15 K

State Permit No. _____

(1) OWNER:

Name Ival Hill
Address Rt. 4, Box 520
Albany, Oregon

(2) LOCATION OF WELL:

County Benton Driller's well number _____
1/4 1/4 Section 15 T. 10S R. 4W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug
Driven Jetted Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded

_____ " Diam. from _____ ft. to _____ ft. Gage _____
10 " Diam. from 1 ft. above land surface to _____ ft.
_____ " Diam. from 29 ft. below land surface to _____ ft.

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Cutting torch
Size of perforations 3/8 in. by 8 in.
40 perforations from _____ ft. to _____ ft.
20 perforations from _____ ft. to 28 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 13 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: Med.
Gravel placed from 18 ft. to 29 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 18 ft. below land surface Date 9/20/66
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Hill
Yield: 75 gal./min. with 8 ft. drawdown after 1 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 29 ft. Depth of completed well 29 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	1'	3'
Brown clay	3'	12'
Brown clay & Med. Gravel	12'	18'
Sand & Med. Gravel (water bearing)	18'	29'

Work started Sept. 19, 1966 Completed Sept. 20, 1966
Date well drilling machine moved off of well Sept. 20, 1966

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ART CLINTON WELL DRILLING CO.
(Person, firm or corporation) (Type or print)

Address Rt. 1, Box 2, Independence, Oregon

Drilling Machine Operator's License No. 34

[Signed] Art Clinton
(Water Well Contractor)

Contractor's License No. 11 Date October 11, 1966