

The original and first copy of this report are to be filed with the

RECEIVED AUG 19 1971

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON

(Please type or print)

(Do not write above this line)

Bent 1821

State Well No. 10/4W-23 ba

State Permit No.

(1) OWNER:

Name Fir View Homes Addition
Address 110 W 2nd, Albany, Oregon

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

8" Diam. from 0 ft. to 384 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [X] Yes [ ] No.

Type of perforator used Torch
Size of perforations 3/16 in. by 12 in.
90 perforations from 85 ft. to 383 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 50 gal./min. with 40 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 83 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 17 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Benton Driller's well number 106871MB
NE 1/4 NW 1/4 Section 23 T. 10S R. 4W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 150 ft.
Static level 60 ft. below land surface. Date 8/4/71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 384 ft. Depth of completed well 384 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Brown clay, Yellow clay, Blue clay, Claystone, Blue sandstone, Grey sandstone, Blue-grey sandstone.

Work started 7/21 1971 Completed 8/4 1971
Date well drilling machine moved off of well 8/4 1971

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Manu Mofsin Date 8-18 1971
Drilling Machine Operator's License No. 719

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Schoen Electric & Pump
Address 626 W. Queen, Albany, Oregon
[Signed] Samy E. Schoen
Contractor's License No. 513 Date 8-18 1971