

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

*Bent
1882*

State Well No. 10/4W-25 R2

State Permit No. 91644

(1) OWNER:

Name Russell Parker
Address 404 North Albany RD.
Albany Oregon

(2) LOCATION OF WELL:

County Benton Driller's well number #183
SE 1/4 SE 1/4 Section 25 T. 10S R. 4 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) **TYPE OF WELL:** Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

12" Diam. from 10" plus 30' to 30' ft. Gage #360
" Diam. from " ft. to " ft. Gage "
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Torch
Size of perforations 3/4" in. by 10" in.
48 perforations from 23' ft. to 29' ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name " Model No. "
Diam. " Slot size " Set from " ft. to " ft.
Diam. " Slot size " Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Concrete
Depth of seal 16' ft. Was a packer used? No
Diameter of well bore to bottom (Two) 12" Each Side Casing
Were any loose strata cemented off? Yes No Depth 16'
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: "
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? Yes No
Type of water? Mod Hard Depth of strata 18'
Method of sealing strata off

(10) WATER LEVELS:

Static level 7' 6" ft. below land surface Date 2* 12-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Ace Drlg
Yield: 650 gal./min. with 2' ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with " ft. drawdown after " hrs.
Artesian flow g.p.m. Date
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing None
Depth drilled 30' ft. Depth of completed well 30' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Surface Soil @ Clay	0	4'
Sand <u>Brown</u>	4	12
Gravel Sand	12	18
Gravel Clean River		
" 2" 5" Diameter	18	30

Work started 2- II-63 19 . Completed 2- 12 1963
Date well drilling machine moved off of well 2- 12- 19 63

(13) PUMP:

Manufacturer's Name " H.P. "
Type: " " " " "

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Ace Drilling Co
(Person, firm or corporation) (Type or print)

Address Albany Oregon

Drilling Machine Operator's License No. 52

[Signed] Bill Hamilton
(Water Well Contractor)

Contractor's License No. 85 Date 2-12, 1963