

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97311
within 30 days from the date
of well completion.

*Best
805*

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

RECEIVED

State Well No. 113/3W-6ba
State Permit No. _____

(Do not write above this line) FEB 1 1977

(1) OWNER:

Name Dave Peet
Address 120 Green acres lane
Albany Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 36 ft. Gage .250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Touch
Size of perforations 1/8 in. by 6 in.
24 perforations from 28 ft. to 34 ft. ft.
perforations from " ft. to " ft. ft.
perforations from " ft. to " ft. ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 20 gal./min. with 5 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 53° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used cement grout
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Benton State Well No. 113/3W-6ba
Driller's well number 52/77/1
NE 1/4 NW 1/4 Section 6 T. 11S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 21 ft.
Static level 21 ft. below land surface. Date 1/19/77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 55 ft. Depth of completed well 55 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	4	
Clay Brown	4	21	
shred Brown + Clay	21	25	
pea gravel + Brown sand	25	35	
Clay Brown	35	53	
Clay gray Hard.	53	55	

Work started 1/18 19 77 Completed 1/21/ 19 77
Date well drilling machine moved off of well 1/22/ 19 77

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Bob Scheler Date 1/29, 19 77
(Drilling Machine Operator)
Drilling Machine Operator's License No. 918

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Bob SCHELER WELL DRILLING.
(Person, firm or corporation) (Type or print)
Address 405 N. Burkhardt Albany Ore.
[Signed] Bob Scheler
(Water Well Contractor)
Contractor's License No. 610 Date 1/29, 19 77