NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be

filed with the STATE ENGINEER, SALEM, OREGON 97310 Within 30 days from the WATER WELL REPORT RECEIVED

STATE OF OREGON OCT & 6 1973 State Well No. 105 4W

of well completion.

(Please type or print) STATE ENGINEE State Permit No. (Do not write above this lineSALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name Parker-Oak Grove Water System/Russel Park	ercounty Linn Driller's well number 2181073D
Address 910 Albany Road	NE 14 NE 14 Section 36 T. 10S R. AW W.M.
Albany, Oregon 97321	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	and the second second of subject to subject to second seco
New Well 🖔 Deepening 🗌 Reconditioning 🗆 Abandon 🖂	
If abandonment, describe material and procedure in Item 12.	(11) WATED TEVEL Commission II
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.
Rotary D Driven D	Depth at which water was first found 22 ft.
Cable C Jetted D Domestic Industrial Municipal XX Dug Bored N Irrigation D Test Well D Other D	Static level 22 ft. below land surface. Date 9-28-73
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
(CASING INSTALLED: Threaded Welded	(19) WELL LOC
12 " Diam. from +5 ft. to 35 ft. Gage .250	(12) WELL LOG: Diameter of well below casing 12!
" Diam. from ft. to ft. Gage	Depth drilled 35 ft. Depth of completed well 35 ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials;
	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? XXYes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Torch	MATERIAL From To SWL
Size of perforations 1/8 in. by 8 in.	Brown top soil (Willamette) 0 10
1 100 perforations from 25 1/2 ft. to 30 1/2 ft.	Sandy loam 10 13
65 perforations from 20 1/2 ft. to 25 1/2 ft.	Sand and pea gravel 13 18
perforations from	1/2 size of gravel 18 31 22
(a) CODERAG	Gray clay 31 35
(7) SCREENS: Well screen installed? Yes No	
Manufacturer's Name	
Type Model No.	<u> </u>
Diam. Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	A
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	<u> </u>
Was a pump test made? 🔲 Yes 🦉 No If yes, by whom?	
Yield: gal./min. with ft, drawdown after hrs.	,
n H H	
" " "	1
Potter test 60	
gai./him. with 201121t. drawdown after & hrs.	Contract to the second of the
Artesian flow g.p.m.	Array and the state of the stat
rature of water 55 Depth artesian flow encounteredft.	Work started 9-26 1973 Completed 9-28 1973
(9) CONSTRUCTION:	Date well drilling machine moved off of well 9-28 1973
Well seal—Material used Cement	Drilling Machine Operator's Certification:
Well sealed from land surface to 20 ft	This well was constructed under my direct supervision
Diameter of well bore to bottom of seal 16 in	Materials used and information reported above are true to my
Diameter of well bore below seal 12 in.	best knowledge and belief. [Signed] Lowr Date 10/24, 1973
Number of sacks of cement used in well seal 35 sacks	[Signed] Date 029, 1973
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No. 594
Brand name of bentonite	725.
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? XXYes ☐ No Plugs Size: location ft.	true to the best of my knowledge and belief. Schoen Electric and Pump
Did any strata contain unusable water? Yes No	Name (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 626, W. Queen/Albany, Oregon 97321
Method of sealing strata off	71.75.71
A STATE OF THE PARTY OF THE PAR	[Signed] Carry & Alsolu
Vas well gravel packed? Yes No Size of gravel:	(Water Well Contractor),
ravel placed from ft. to ft.	Contractor's License No. 513 Date 10/24, 1973