NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED FEB 11 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

Bent 2109

State Well No. 10/5W-13E

State Permit No.

(1) OWNER:
Name Albert Armstrong
Address 3370 Spicer Rd
Albany Oregon

(2) LOCATION OF WELL:
County N.W. Benton Driller's well number ?
SW ¼ NW ¼ Section 13 T. 10S R. 5 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +1.6 ft. to 28 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No
Type of perforator used torch
Size of perforations 1/2 in. by 4 in.
15 perforations from 19 ft. to 23 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. X Slot size X Set from X ft. to X ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement Grout
Depth of seal 2 ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from X ft. to X ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Soft Depth of strata 23'
Method of sealing strata off

(10) WATER LEVELS:
Static level ? ft. below land surface Date 2-10-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 58 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 28 ft. Depth of completed well 28 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sand & Gravel	19	22
New Basalt	22	28

Work started 2-6 1964 Completed 2-10 1964
Date well drilling machine moved off of well 2-10 1964

(13) PUMP: ?
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Ace Drilling Co. (Person, firm or corporation) (Type or print)
Address Albany Oregon
Drilling Machine Operator's License No. 132
[Signed] Bill Hamilton (Water Well Contractor)
Contractor's License No. 85 Date 2-12, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)