NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)





(10) LOCATION OF W *** ***

(1) OWNER:	(10) LOCATION OF WELL:
Name Childrens Farm Home	County Benton Driller's well number
Address 4455 NE Highway 20	SW 1/4 NE 1/4 Section 18 T. 10S R. 5W W.M.
Corvallis, OR 97330	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well 🔀 Deepening 🗌 Reconditioning 🔲 Abandon 🗌	· · · · · · · · · · · · · · · · · · ·
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 45 ft.
Rotary Driven D Domestic Municipal Domestic	Static level 29 ft. below land surface. Date 4/14/80
Cable	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded [] Welded []	(12) WELL LOG: Diameter of well below casing 6
<u>6 "Diam. from</u> <u>0</u> ft. to <u>60</u> ft. Gage <u>250</u>	65
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
(6) PERFORATIONS: Perforated? Yes D No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used torch	MATERIAL From To SWL
Size of perforations 1/8 in. by 6 in.	Top Soil 0 2
24 perforations from 52 ft. to 58 ft.	Brown Sticky Clay 2 38
perforations from ft. to ft.	Med. sand & sm. gravel 38 45
perforations from ft. to ft.	Med. sand & grave1 45 57 291
(7) SCREENS: Well screen installed?	Med. sand (cemented) 57 65
Manufacturer's Name	· · · · · · · · · · · · · · · · · · ·
Type	
Diam. Slot size	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes X No If yes, by whom?	1.1" A 1 1980
eld: gal./min. with ft. drawdown after hrs.	WATED FESOURCES DEPT
	SALEN, CREGON
<u>"" "</u> " "	
Air BMEr test 30 gal./min. with 27 ft. drawdown after 1 hrs.	
tesian flow g.p.m.	Ч м
Temperature of water 54 Depth artesian flow encountered ft.	Work started 4/14 1980 Completed 4/14 1980
(9) CONSTRUCTION:	Date well drilling machine moved off of well $4/14/80$ 19
Well seal-Material used Cement	Drilling Machine Operator's Certification:
Well sealed from land surface to30	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal <u>10</u> in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	[Signed] Storres M. Sumpson Date 4/16/80 19
Number of sacks of cement used in well seal	(Dilling Machine Operator)
How was cement grout placed?	Drilling Machine Operator's License No. <u>1072</u>
from bottom to top	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? 🗄 Yes 🗌 No Plugs	Name Schoen Electric, Inc
Did any strata contain unusable water? 🔲 Yes 🎽 No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 626 W Queen Ave., Albany, OR 97321
Method of sealing strata off	[Signed] Same Allon
Was well gravel packed? 📋 Yes 👿 No 🦳 Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. <u>513</u> Date <u>4/16/80</u> , 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119