NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

Bent STATE OF OPE

(Do not write above this line)

	١.
 	Well No. 105/6W-21
State	Well No. USIOW W
	· , ,
State	Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name James W. Lyday	County Benton Driller's well number
Address Rt. 1, Box 52	14 14 Section 21 T. 10s R6W W.M.
Philomath, Or.	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well 조조 Deepening 🛘 Reconditioning 🗘 Abandon 🖂	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 92 ft.
Rotary 📆 Driven 🗆 Domestic 🖫 Industrial 🗀 Municipal 🗀	Static level 8 ft. below land surface. Date 11/20/7
Jetted	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded Welded Welded	(12) WELL LOG: Diameter of well below casing 6!! Depth drilled 100 ft. Depth of completed well 100 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	gravel 0 1
perforations from ft. to ft.	brown clay 1 4
perforations from ft. to ft.	brown clay & grit 4 12
perforations from ft. to ft.	gray clay 12 15 gray claystone 15 35
(7) SCREENS: Well screen installed? ☐ Yes ☑XNo	hd gray sandstone 35 75
Manufacturer's Name	gray sandstone 7 gpm 75 190
Type Model No	STAY BOLLOW PORTS
Diam Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made?XX Yes XX o If yes, by whom? G&W	nfc 11 1979
eld: 7 gal./min. with 80 ft. drawdown after 2 hrs.	WATER RESOURCES DEFT
n n	SALEM, OREGUN
<i>n n</i>	Grantity Grant
ler test gal./min. with ft. drawdown after hrs.	
esian flow g.p.m.	
Temperature of water 52 Depth artesian flow encountered ft.	Work started 77/20/19 79 Completed 77/20/19 79
(9) CONSTRUCTION:	Date well drilling machine moved off of well 11/20/ 19 79
Well seal—Material used cement	Drilling Machine Operator's Certification:
Well sealed from land surface to 18 ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal $\frac{10}{2}$ in.	best knowledge and belief
Diameter of well bore below seal	[Signed] Date 11/30/1979.
Number of sacks of cement used in well sealsacks	Drilling Machine Operator's License No. 503
How was cement grout placed? pressure	Dilling Flavour of Delays and Del
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.	NameRaymond C. Gellatly & Ronald S. Witham
Did any strata contain unusable water? Yes X No	(Person, firm or corporation) (Type or print) Address P.O. Boxl. Philomath, Or. 97370
Type of water? depth of strata	Address Boxl, Philomath, Gr. 9(310
Method of sealing strata off	[Signed] MINA Silvat
Was well gravel packed? Tyes XNo Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No Date