

WATER WELL REPORT
STATE OF OREGON

Do Not Destroy
Bent
2341

RECEIVED

JUL 5 1983

State Well No.

10S-6W-33

WATER RESOURCES DEPT.

PLEASE TYPE or PRINT

SALEM, OREGON

(1) OWNER:

Name Fred Beazell
Address 3029 Chintimini
City Corvallis State Or.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
Cable Bored Thermal: Withdrawal ReInjection

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded

6" Diam. from 0+1 ft. to 29 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal/min. with ft. drawdown after hrs.
" " " " " "
Test 10 gal/min. with drill stem at 126 ft. 2 hrs.
Bailer test gal/min. with ft. drawdown after hrs.
Artesian flow g.p.m.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used cement
Well sealed from land surface to 28 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? pressure

Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Benton Driller's well number
Tax Lot # 1/4 Section 33 T. 10S R. 6W W.M.
Lot Blk Subdivision

(11) WATER LEVEL: Completed well.

Depth at which water was first found 126 ft.
Static level 45 ft. below land surface. Date 6/20/83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing ... 6"

Depth drilled 131 ft. Depth of completed well 131 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown clay & grit	0	4	
brown clay	4	10	
gray clay	10	18	
brown sandstone	18	26	
gray sandstone	26	65	
hd gray basalt	65	110	
gray basalt	110	125	
broken brown basalt	126 gpm	125	131

Work started 6/20/1983 Completed 6/20/1983
Date well drilling machine moved off of well 6/20/1983

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ronald S. Witham Date 6/30/83

Bonded Water Well Constructor Certification:
Bond 503 Issued by: Lystra Ins.
(number) Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Raymond C. Gellatly & Ronald Witham
(Person, firm or corporation) (Type or print)
Address P.O. Box 1, Philomath, Or.
[Signed] Ronald S. Witham
Water Well Constructor
Date 6/30/1983

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*45292-690