

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
JUN 16 1964
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

Permit
2589
State Well No. 11/4w-7
State Permit No.

(1) OWNER:
Name William Benson
Address
Corvallis, Oregon

(2) LOCATION OF WELL:
County Benton Driller's well number
¼ ¼ Section 7 T. 11s R. 4w W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 41 ft. Gage STD

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used acetylene torch
Size of perforations ¼ in. by 6 in.
64 perforations from 30 ft. to 39 ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal bentonite and cement
Depth of seal 22 ft. Was a packer used? no
Diameter of well bore to bottom of seal 1.0 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4
Gravel placed from 24 ft. to 28 ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 15 ft. below land surface Date 10-29-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 80 gal./min. with 7 ft. drawdown after 2 hrs.
" 100 " " 12 " 2 "
" 120 " " 17 " 2 "
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing
Depth drilled 41 ft. Depth of completed well ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
topsoil	0	2
grey clay	2	8
yellow clay	8	15
grey clay and sand	15	19
grey sand	19	25
sand and gravel	25	31
brown sand and fine gravel	31	39
clay below		

Work started 10-21-63 Completed 10-29-63 19
Date well drilling machine moved off of well 10-29-63 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Raymond C. Gollatly (Person, firm or corporation) (Type or print)
Address Box 1 Philomath, Oregon
Drilling Machine Operator's License No. 76
[Signed] Raymond C. Gollatly (Water Well Contractor)
Contractor's License No. 77 Date 11-9-63, 19