NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Permit No.

(1) OWNER: Raintree Estates	(10) LOCATION OF WELDEPT.	- l= c l=	
Name delication of the control of th	County Benton CoEC Challer's well n	$_{\rm umber}$ F/76/ $_{\rm U}$	
Address 765 N.W. 5th St.		R. 5W $W.$	
Corvallis, Oregon 97330	Bearing and distance from section or subdivisi	lon corner	
(2) TYPE OF WORK (check):			
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐			
If abandonment, describe material and procedure in Item 12.	(11) THAMED TRIVEL OF 1		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed w	zell. 100	
Rotary Driven Domestic Industrial Municipal	Static level 20 ft. below land	10101	
Cable		-	
	Artesian pressure lbs. per square	re inch. Date	
CASING INSTALLED: Threaded □ Welded ☑	(12) WELL LOG: Diameter of well	6	
6" Diam. from0 ft. to40 ft. Gage250	Didnieder of well below casing		
	Depth drilled 140 It. Depth of completed well 140 It.		
	Formation: Describe color, texture, grain size	and structure of materia	
	and show thickness and nature of each stratu with at least one entry for each change of forma	m and aquifer penetrate	
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	cipal water-bearing strai	
Type of perforator used	MATERIAL	From To SWL	
Size of perforations in. by in.			
	-Topsoil	0 3	
perforations from	Light brown clay&boulders	3 8	
perforations from	Red clay &boulders	8 33	
perforations from ft. to ft.	Blue basalt	33 60	
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	Cong basalt	60 130	
Manufacturer's Name	-Grey basalt	130 160	
Type Model No	Blue basalt	160 180	
Diam. Slot size Set from ft. to ft.	Grey basalt	180 230	
Diam. Slot size Set from ft. to ft.	Cong_basalt	230 260	
16. 10	Grey basalt	260 278	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Cong basalt	278 340	
Was a pump test made? Yes X No If yes, by whom?			
ft. drawdown after hrs.	, :		
" " "			
" Tested with air: could fluctuate "			
Butter test 20 gal./min. with 320st. drawdown after 4 hrs.			
rtesian flow g.p.m.			
nperature of water Depth artesian flow encountered ft.	Work started 12/6/76 19 Complete	ed 12/10/76 ₁₉	
(9) CONSTRUCTION:	Date well drilling machine moved off of well	12/10/76 19	
Well seal—Material usedCement	Drilling Machine Operator's Certification:		
Well sealed from land surface to 38 ft.	This well was constructed under my Materials used and information reported	direct supervision	
Diameter of well bore to bottom of sealin.	Materials used and information reported	above are true to m	
Diameter of well bore below seal	best knowledge and belief	- 40 lar lac	
	[Signed] Date 12/15/7,69 (Drilling Maching/Operator)		
Number of sacks of cement used in well seal sacks Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No. 829		
Brand name of bentonite	Water Well Contractor's Certification:		
Number of pounds of bentonite per 100 gallons of water	This well was drilled under my jurisdi	ction and this report	
	true to the best of my knowledge and bel	ief.	
Was a drive shoe used? ▼Yes □ No Plugs Size: location ft.	Name Corvallis Drilling Co. In	nc.	
Did any strata contain unusable water? Yes No	(Person, firm or corporation)	(Type or print)	
Type of water? depth of strata	Address 3440 SW 3rd St. Corvall	is, Oregon 97330	
Method of sealing strata off	[Signed] Lelantera A Kunn	n111	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Contr	actor	
Gravel placed from ft. to ft.	Contractor's License No 560 Date	12/15/76 19	